



nVent HOFFMAN A72XN7318FSLP Low Profile Type 1 Disconnect Enclosures Instruction Manual

[Home](#) » [nVent HOFFMAN](#) » nVent HOFFMAN A72XN7318FSLP Low Profile Type 1 Disconnect Enclosures Instruction Manual 

Contents

- [1 nVent HOFFMAN A72XN7318FSLP Low Profile Type 1 Disconnect Enclosures](#)
- [2 Product Information](#)
- [3 Product Usage Instructions](#)
- [4 Dimension](#)
- [5 Documents / Resources](#)
 - [5.1 References](#)
- [6 Related Posts](#)



nVent HOFFMAN A72XN7318FSLP Low Profile Type 1 Disconnect Enclosures



Product Information

The product is an enclosure designed for the installation of disconnect devices, external mounting feet, or conduit hubs that have the same environmental rating as the enclosure. It is available in free-standing configuration with one or two doors. The enclosure depth varies depending on the model, ranging from 12 inches to 24 inches.

Product Usage Instructions


- 1. Ensure that only listed or recognized disconnect devices, external mounting feet, or conduit hubs with the same environmental rating as the enclosure are installed in any opening.
- 2. Follow the installation instructions provided by the device manufacturer to ensure compliance.
- 3. For variable depth disconnects, use the connecting rods provided and cut them to the appropriate length to fit the enclosure depth. Refer to the table below and the manufacturer’s instructions for guidance.

Enclosure Depth and Flange to Panel Depth

Enclosure Depth	C Flange to Panel Depth
12 inches	9.15 inches
18 inches	15.15 inches
24 inches	21.15 inches

Consult the manufacturer’s mounting information for the specific disconnect switch or circuit breaker to be installed.

Dimension




NOTICE: To maintain the environmental rating of this enclosure, install in any opening, only listed or recognized disconnect devices, external mounting feet, or conduit hubs that have the same environmental rating as the enclosure. Install in compliance with the installation instructions of the device.

Bulletin	Enclosure Description	Enclosure Depth “C”	Flange to Panel Depth “D” (1)
A38P	Free–Standing, one and two –door	12	9.15
		18	15.15
		24	21.15

1. This depth dimension is used to calculate the length of the connecting rod(s).

PH: 763 422 2211
nVent.com/HOFFMAN

Documents / Resources

	nVent HOFFMAN A72XN7318FSLP Low Profile Type 1 Disconnect Enclosures [pdf] Instruction Manual A72XN7318FSLP, A72XN7318FSLP Low Profile Type 1 Disconnect Enclosures, Low Profile Type 1 Disconnect Enclosures, Profile Type 1 Disconnect Enclosures, 1 Disconnect Enclosures, Enclosures
--	---

References

-  [We connect and protect | nVent](#)