



PATTERSON V-Series HVLS Fan Instruction Manual

[Home](#) » [PATTERSON](#) » PATTERSON V-Series HVLS Fan Instruction Manual 

Contents

- 1 PATTERSON V-Series HVLS Fan
- 2 IMPORTANT SAFETY INFORMATION
- 3 DAMAGED EQUIPMENT
- 4 ITEMS INCLUDED IN YOUR FAN KIT
- 5 TOOLS NEEDED
 - 5.1 FAN SPACING, PLACEMENT, & CLEARANCE
- 6 MAINTENANCE
- 7 BAR JOIST MOUNTING
- 8 MOTOR ASSEMBLY
- 9 GUY WIRE ASSEMBLY
- 10 ELECTRICAL INSTALLATION
- 11 Documents / Resources
 - 11.1 References



PATTERSON V-Series HVLS Fan



BEFORE YOU START

IMPORTANT SAFETY INFORMATION

READ BEFORE OPERATING THE FAN AND SAVE THESE INSTRUCTIONS

- Read and understand these instructions before installing or operating a fan unit. Installation, adjustment, repair or maintenance must be performed by qualified personnel.
- Follow all safety practices and instructions during the installation, operation and servicing of the fan. Failure to apply these safety practices could result in death or serious injury. If you do not understand the instructions, please call your Patterson Sales Rep for guidance.
- All fan controls and incoming power should be installed only by qualified technicians familiar with the requirements of the National Electrical Code and local codes. Failure to follow these guidelines will void the manufacturer's warranty.
- All electrical controls are configured at the factory and are ready to use. No user adjustments are available. Follow the included installation instructions when installing this device to ensure proper operation. Do not make any changes to any part of the fan without first consulting Patterson Fan. Installation is to be in accordance with the National Electrical Code, ANSI/NFPA and applicable local codes.
- The user is responsible for compliance with all international and National Electrical Code requirements with respect to grounding of all equipment. Many of the parts of this unit operate at line voltage. **DO NOT TOUCH.** Install all covers before applying power or starting and stopping the unit. To reduce the risk of electric shock or injury, use this unit only in the manner intended by the manufacturer. If you have questions, call your Patterson Sales Rep at 1-800-768-3985.
- Before servicing or cleaning the unit, switch power off at the service panel and lock the service disconnecting means to prevent power from being switched on accidentally. When the service disconnecting means cannot be locked, securely fasten a prominent warning sign, such as a tag, to the service panel. At all times, leave the power off at the service panel. To reduce the risk of electric shock or injury, use this unit only in the manner

intended by the manufacturer. If you have questions, call your Patterson Sales Rep at 1-800-768-3985.

DAMAGED EQUIPMENT

Do not operate or install any fans or fan accessories that appear to be damaged. Failure to follow this instruction can result in death, serious injury, or equipment damage. Call your Patterson Sales Rep at 1-800-768-3985 immediately for guidance.

SERVICE

- If the fan does not operate properly using the procedures in this manual, remove all power to the unit and call your Patterson Sales Rep at 1-800-768-3985.
- Keep all body parts clear of moving parts at all times. All electrical troubleshooting and repair must be done by a qualified technician and meet all applicable codes.

KEY RETENTION SYSTEM COMPONENTS

- Our fans are engineered with key features to prevent pieces of the fan from falling in the unlikely event of a catastrophic failure. Used together, these systems provide comprehensive protection of people, equipment and property.
- Install the safety cable on EVERY fan. The safety cable, if installed per Patterson Fan specifications, will prevent the fan from falling in the unlikely event that the mounting system should fail.
- The fan should never be run without a properly installed safety cable, which is supplied with every fan along with all required hardware. If the safety cable is not installed, the warranty will be voided.

MARK THE FLOOR TO ALERT PERSONNEL

- When mounting a fan in an area where materials may be elevated into its path, we recommend alerting personnel of the overhead location of fans by marking the floor.

WEIGHT CONSIDERATIONS

- If there is any uncertainty in the strength of the building structure, a professional structural engineer should perform a thorough evaluation of the building prior to purchasing the fans. Patterson Fan provides guidelines for mounting fans; however, it is the sole responsibility of the building owner and installer to ensure the safety of the mounting system, that the building structure is sound, and that the installation complies with all federal, state, and local codes.

WARNING

- If unusual oscillating movement is observed, immediately stop using the fan and contact your Patterson Sales Rep at 1-800-768-3985.


CHECK FEDERAL, STATE, AND LOCAL CODES

- Check all relevant codes to make sure that all product certifications, product listings, and building regulations are met. Code compliance is the responsibility of the installer.

WINDY CONDITIONS

- Fans should not be operated in windy conditions or installed in locations where it is frequently windy.

ITEMS INCLUDED IN YOUR FAN KIT



TOOLS NEEDED



- Hand tools (provided)
- Level or plumb bob
- Torque wrench

1. Concrete/wood beam bracket (hardware not provided)
2. Universal/bar joist bracket & hardware
3. Hand tools
4. Downrod
5. Wingtips & hardware
6. Electrical cable & disconnect
7. Safety cable & hardware


FAN SPACING, PLACEMENT, & CLEARANCE

SPRINKLER SYSTEMS AND FAN PLACEMENT

- In any installation where fire sprinklers are in place, the fan should not interfere with their correct operation. Fans should be located no less than 3 feet below a sprinkler, and placed in the center of nearest four sprinklers. Our industrial control panel can be connected to a fire relay system, which, in an emergency, will stop fans in case of fire.
- Prior to installing fans, review all codes applicable to sprinkler systems and fans to ensure code compliance and refer to NFPA 13 Standard from the National Fire Prevention Association. It is your sole responsibility to see that the installation is completed to code and that it is correct.

OTHER INFORMATION ON PLACEMENT AND SPACING

- If possible, avoid mounting fans directly below lights or skylights to avoid any strobe effect caused by moving airfoils. Please see chart below for recommended minimum and maximum hanging heights.
- If the building has a mezzanine, fans should be mounted so a person cannot reach a fan in any way from the upper level/deck. Make certain that fans are positioned so that the airfoil tips are at least 3 feet away from any area where a person may be able to extend outward to reach them.
- Fans should not be located directly beneath any air supply outlets or exhausting outlets. This includes air conditioning units and evaporative coolers. Such equipment can be used effectively in conjunction with HVLS fans but the discharge must be located outside of the swept area of the fan. Exhaust fan inlets or other return air points creating a negative pressure should not be within 1.5 times the diameter of the fan.



| Size | H (min) | H (Rec max) | Assembled Height | A | B | C | D | Downrod |
|------|---------|-------------|------------------|-----|-----|----|----|-----------|
| 8' | 10' | 16.5' | 31.5" | 14" | 12" | 8" | 8" | 2' to 5' |
| 12' | 10' | 16.5' | 31.5" | 15" | 12" | 8" | 8" | 2' to 5' |
| 16' | 12' | 20' | 31.5" | 16" | 12" | 8" | 8" | 2' to 6' |
| 20' | 14' | 23' | 37" | 20" | 12" | 8" | 8" | 2' to 10' |
| 24' | 14' | 30' | 37" | 20" | 12" | 8" | 8" | 2' to 10' |

MAINTENANCE

- We strongly recommend that all equipment be included in your company's preventative maintenance program. Prior to performing any maintenance on the fan, it **MUST** be disconnected from the power source by means of the separate lockable disconnect (provided).

AIRFOIL CLEANING

- Depending on the application of the fan, there can be quite a bit of dust or other particulates that cling to the fan's airfoils. We recommend fan owners keep airfoils clean by having a maintenance person or skilled trade professional – who has experience using a lift – wipe the fan airfoils with a rag or sponge using hot water or regular cleaning solutions. Please do not use chlorine or any chemicals containing chlorine.

RETENTION SYSTEM CHECK

- Each fan must be installed with a retention system. The safety cable is attached to the motor and wraps around the building structure. The safety cable is an important part of the safety system and protects users if a catastrophic event occurs. It is critical for fan owners to ensure that it is intact and properly secured.

REPLACEMENT PARTS

- Please call your Patterson Sales Rep at 1-800-768-3985 for parts.

BAR JOIST MOUNTING

- **Note:** For other mounting options, please call your Patterson Rep at 1-800-768-3985.


1. Insert two bolts through one side of the bar joist mount and one beam clamp. Select the appropriate holes on the mount based on structure width; install bolts as close to bar joist as possible.
2. Place mount around bar joist and secure the remaining two bolts through the remaining beam clamp. Torque all four bolts to 32 ft-lbs.
3. Place the two top bolts of the downrod (image 3) into the bolt opening of the mount (image 4). Do not tighten completely.



MOTOR ASSEMBLY

- **Note:** To avoid damaging the motor during installation, do not remove protective plastic from the motor until it has been properly mounted.
- **Note:** If using an extended downrod, see page 11 for guy wire bracket installation before proceeding with motor assembly below.

1. Remove the two bolts on the bottom of the downrod. Slide motor shaft inside downrod so that motor leads are aligned with junction box above.
2. Line up safety ring bracket, downrod, and motor shaft bolt holes. Replace the two bolts.
3. With a level or plumb bob, make sure downrod is completely vertical. Torque all four downrod bolts (top and bottom) to 32 ft-lbs.



SAFETY RETENTION SYSTEM

- **Note:** This step is required. Failure to install the safety cable may void the manufacturer's warranty.
- **WARNING:** Do not put too much tension on the safety cable. A small amount of slack is needed for the safety cable to properly function. Avoid sharp edges.


1. Wrap safety cable around beam or building structure.
2. Run safety cable through the holes in top of safety ring bracket and around downrod.
3. Overlap safety cable and secure with cable clamps.



GUY WIRE ASSEMBLY

WARNING: If you order an extended downrod, guy wire installation becomes required for safe fan operation.

1. During Step 2 of MOTOR ASSEMBLY, add guy wire brackets to the top bolt of the motor shaft. The guy wire brackets come with extra washers that should be placed between the guy wire brackets and safety ring bracket. Bolt should be torqued to 32 ft-lbs per Step 3 of MOTOR ASSEMBLY.
2. Using the quick links, connect the turnbuckles to the outer holes of the guy wire brackets.
3. Loosen jam nuts and extend turnbuckle.
4. Run four guy wires to ceiling structure, keeping the angle less than 45° for maximum stability. Attach guy wires to ceiling structure using provided beam clamps and thimble.
5. Remove slack and secure with cable clamps.
6. Once all guy wires are in place, use turnbuckles to take out any remaining slack. Periodically check the fan assembly with a level to ensure it remains in the vertical position. Continue adjusting by means of the turnbuckles until all cables are satisfactory. Guy wires should be taut, but not over stressed. Recheck all cable clamps for tightness.
7. Tighten all jam nuts. This step is required. Failure to install the guy wires properly may void manufacturer's warranty and become a safety hazard.




BLADE ASSEMBLY

1. Insert wingtips into the end of the blades and lock into place with screw.
2. Remove blade bolts from tang. Loosen safety strap bolts and insert blade onto tang. Install the two blade bolts and double washer from below as shown Image 17. Torque to 16 ft-lbs.
3. Install washer and nut on top of blade bolt. Torque to 16 ft-lbs. Do not torque blade bolts and nuts at the same

time.

4. Torque safety strap bolts to 16 ft-lbs.




ELECTRICAL INSTALLATION

BREAKER SIZING



Refer to the table below for recommended circuit breaker sizing based on input voltage and fan motor horsepower.

| VFD Model | Input V | Input Max Amp/ Recommended Fuse | Output V | Max Output A |
|-------------|---------------------|---------------------------------|-------------|--------------|
| EM30 Series | 220V, 1Ø, .5 HP | 10/15 | 0-Input, 3Ø | 4.5 |
| EM30 Series | 208-230V, 3Ø, .5 HP | 5/10 | 0-Input, 3Ø | 4.5 |
| EM30 Series | 460V, 3Ø, .5 HP | 3/10 | 0-Input, 3Ø | 2 |
| EM30 Series | 220V, 1Ø, 1HP | 14/20 | 0-Input, 3Ø | 7 |
| EM30 Series | 208-230V, 3Ø, 1 HP | 7.8/15 | 0-Input, 3Ø | 7 |
| EM30 Series | 460V, 3Ø, 1 HP | 5/10 | 0-Input, 3Ø | 4 |

CONNECT CONTROL CABLE TO FAN MOTOR



1. Remove the cover of the motor junction box on the downrod.
2. Feed motor leads through strain relief into junction box.
3. Pass end of VFD cable with ring terminals through strain relief into junction box.
4. Attach ring terminals from motor leads and VFD cable to terminals in junction box. Ensure letters match. See Image 18.
5. Route VFD cable to suitable VFD location (50' of cable has been provided). Conduit is recommended.
6. Mount VFD to wall by use of attached mounting tabs (hardware not included).
7. Run VFD cable through strain relief furthest to right. Connect cable to terminal blocks U, V, and W. See Images 19 and 20.



RUN INPUT POWER CABLE & INSTALL LOCKABLE DISCONNECT

WARNING: The Lockable Disconnect must be installed per local electrical codes. AT MINIMUM it must be installed outside the diameter of the fan blades.

- 1.
2. Be sure to size the input power cable properly for the application. Most installations will require 12-gauge wire. However, longer runs of power cable may require 10-gauge or higher.
3. Run input power into the top of the Lockable Disconnect, using the appropriately sized knockout.
 - **3A (THREE PHASE)**
 - Connect conductors to terminals L1, L2, and L3, respectively. Ground wire should be fastened to one of the ground terminals. Continue running input power to the drive by connecting three conductors to terminals T1, T2, and T3, respectively. A ground wire should be fastened to the ground terminal.
 - **3B (SINGLE PHASE)**
 - Connect conductors to terminals L1 and L2, respectively. Ground wire should be fastened to one of the ground terminals. On the output side, T2 should be looped back to input L3. Continue running input power to the drive by connecting two (2) conductors to terminals T1 and T3, respectively. A ground wire should be fastened to the ground terminal.
4. Run the rest of the input cable near the wall mounted VFD. Using conduit for this run is recommended.
 - **5A (THREE PHASE)**
5. Connect the opposite end of the input power cable to the VFD. The three conductors should be connected to L1, L2, and L3, respectively. The ground wire should be connected in the manner shown in Image 19.
 - **5B (SINGLE PHASE)**
 - Connect the opposite end of the input power cable to the VFD. The two conductors should be connected to L1/L and L2/N, respectively. The ground wire should be connected in the manner shown in Image 20.
6. Reconnect Cat5 keypad cable to VFD and reattach cover.

CONNECT VFD TO A FIRE SUPPRESSION SYSTEM (If required)


- **WARNING:** DO NOT connect external voltage to the fire suppression terminals. Fire suppression terminals should be connected to a relay via contacts. Placing voltage on the VFD terminal block will destroy the unit and void all manufacturers' warranties.
 - **CAUTION:** DO NOT connect Patterson V-Series fans to the fans of another company for purposes of fire suppression. A separate line must be run for Patterson fans ONLY.
 - **CAUTION:** If the drive will not be connected to any fire suppression system, the factory installed jumper across COM and DI2 MUST remain in place.
1. Remove the factory installed jumper between terminals COM and DI2 on the terminal block behind the cover of the VFD. Refer to Image 21.



2. Connect the fire suppression system wires from the dry contacts on the relay to terminals COM and DI2. Route the fire system cable out via the provided strain relief.
3. Drive is now wired to shut down upon activation of any fire suppression signal. VFD expects a close contact in order to run.

pattersonfan.com 800.768.3985

Documents / Resources

| | |
|---|--|
|  | <p>PATTERSON V-Series HVLS Fan [pdf] Instruction Manual V-Series HVLS Fan, V-Series, HVLS Fan, Fan</p> |
|---|--|

References

-  [Patterson Fan Co. - Industrial Fan Manufacturer - Industrial Air Cooling Solutions](#)
-  [Patterson Fan Co. - Industrial Fan Manufacturer - Industrial Air Cooling Solutions](#)