



pdk RPE Red Pedestal Ethernet Controller User Guide


[Home](#) » [pdk](#) » pdk RPE Red Pedestal Ethernet Controller User Guide 

pdk RPE Red Pedestal Ethernet
Controller User Guide



Quick Start Guide





View the user manual here:
prodatakey.zendesk.com

PN: RPE


www.prodatakey.com
801.317.8802

Copyright © 2022 ProdataKey Inc. All rights reserved. Pdk, Pdk io, and the Red logos are trademarks of ProdataKey Inc.

REV 12302022

prodatakey.zendesk.com
www.prodatakey.com

Package Contents



Red Pedestal
Controller (1)




Jumpers (4)



Bolts (4)




Nuts (4)



Diodes (2)



Battery Leads (1)



Transformer (1)
14 VDC, 2 Amp


Mounting Controller

Reader Connection

to the controller. Wire the DPS to the controller as shown above. For reporting double doors, wire the two door position in series and connect to the controller.

B AUX Input – A software rule can be programmed to trigger events or outputs based on input triggers.

Input B / REX Connection



A Maglock – When installing a Maglock, it is typical to install a REX (request to exit) at the door for free egress. Run an 18/2 wire from the maglock to the controller and REX as shown.


B REX (Request to Exit) – The REX is mounted at your desired location with an 18/5 wire. Wire the REX to the controller and maglock as shown above. If reporting is not needed in the system, simply eliminate the green input wire.

C Jumper Block – Use to designated (+) or (-) board voltage out of NO and NC.

If the jumper is off, the relay is a standard dry contact requiring an input into C on the relay.

D AUX Input – A software rule can be programmed to trigger events or outputs based on input triggers.

Locking Relay



A Gate Operator – Follow the gate operator wiring instructions to connect the gate operator to an ELK 912B Isolation Relay.


B Isolation Relay – Installation of an ELK 912B isolation relay is recommended to prevent electrical damage to the Red Gate. The isolation relay is sold separately.

C Locking Relay – Connect the ELK 912B isolation relay to the controller by connecting the positive wire into a positive port and the negative wire into the NO port on the board.

D Jumper Block – Use to designated (+) or (-) board voltage out of NO and NC.


If the jumper is off, the relay is a standard dry contact requiring an input into C on the relay negative (-) and center pins.

Communication Connections



A Ethernet – All Red controllers come with a built-in RJ45 connection for network connectivity. Once connected, the Red controller is Self-Discoverable from pdk.io using IPV6. Alternatively, you may use IPV4 or assign a static IP using pdk.io if desired.

Power Connection



A DC INPUT – Input 12-24 VDC power using an 18/2 wire. For high voltage applications, use the High Voltage Converter (PN: HVC).

B BATTERY – The enclosure will fit most 12 VDC 1.2 Ah batteries. Connect the battery to the controller using the supplied battery leads.

Reference Guide

Fire Input – To integrate the fire system into a controller, refer to wiring diagrams at www.prodatakey.zendesk.com

Programming – After the controller is connected, access the configuration software as instructed in the programming manual available at www.prodatakey.zendesk.com

Reader Compatibility – PDK does not require proprietary readers. Controllers accept a Wiegand input, including biometric readers and keypads. OSDP readers are supported by using included jumper (see OSDP reference guide). Contact pdk support if assistance is needed.

UL 294 Compliance – All equipment must meet appropriate UL certifications. For UL listed installations, all cable runs must be less than 30 meters (98.5')

Part Number – RPE

PDK Technical Support

Phone: 801.317.8802 option #2

Email: support@prodatakey.com

PDK Knowledge Base: www.prodatakey.zendesk.com

OSDP Reference Guide

What is OSDP – Open Supervised Device Protocol (OSDP) is an access control communications standard developed by the Security Industry Association to improve interoperability among access control and security products. OSDP brings heightened security and improved functionality. It is more secure than Wiegand and supports AES-128 encryption.

OSDP Wire Specification – Four-conductor twisted-pair with overall shield is recommended to remain fully TIA-485 compliant at the maximum supported baud rates and cable distances.

NOTE – It's possible to reuse existing Wiegand wiring for OSDP, however, using simple stranded cable typical of Wiegand readers generally does not meet the RS485 twisted pair recommendations.

OSDP Multi-Drop – Multi-drop gives you the capability to accommodate many readers by running one length of four-conductor cable, eliminating the need to run wire for each wire.


NOTE – The maximum number of readers each port can support is four.

NOTE – Wiegand readers will not work when OSDP jumpers are installed.

Contents

- 1 Documents / Resources
- 1.1 References

Documents / Resources

	<p>pdk RPE Red Pedestal Ethernet Controller [pdf] User Guide</p> <p>RPE Red Pedestal Ethernet Controller, RPE, Red Pedestal Ethernet Controller, Pedestal Ethernet Controller, Ethernet Controller</p>
-------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

References

-  pdk.io
-  [Cloud-based Access Control | ProdataKey | United States](#)