



Contents [[hide](#)]

- [1 Precision Electric Variable Frequency Drives](#)
- [2 Product Information](#)
- [3 Product Usage Instructions](#)
- [4 Introduction](#)
- [5 How Variable Frequency Drives Work](#)
- [6 Key Benefits of Using VFDs](#)
- [7 Technical Specifications and Standards](#)
- [8 Real-World Applications and Case Studies](#)
- [9 Best Practices for VFD Implementation](#)
- [10 Conclusion](#)
- [11 References](#)
- [12 Frequently Asked Questions](#)
- [13 Documents / Resources](#)
 - [13.1 References](#)



Precision Electric, Inc.

Precision Electric Variable Frequency Drives



Product Information

Technical Specifications

- **Manufacturer:** Precision Electric, Inc.
- **Contact:** 5742561000
- **Website:** www.precision-elec.com

Product Overview

Variable Frequency Drives (VFDs) are devices that control the speed of an electric motor by varying the frequency and voltage supplied to the motor. They offer benefits in energy savings, equipment protection, and process improvement.

Product Usage Instructions

Key Benefits of Using VFDs

- Reduced annual energy costs by 48%.
- Extended pump seal life by two years.
- Significant energy and maintenance savings by matching motor output to actual needs.
- Enhanced flexibility in process control.

Technical Specifications and Standards

- When selecting or applying a VFD, consider the following technical specifications.
- **Input Harmonics and IEEE 519:** Understand the impact of non-linear current drawn by VFD rectifiers on harmonics and industry standards like IEEE 519 for harmonic limits in power systems.

Introduction

- What is a frequency drive? In industrial contexts, “frequency drive” usually refers to a Variable Frequency Drive (VFD) – an electronic controller that adjusts the speed of an AC motor by modulating the frequency and voltage of the power supplied [1](#).
- By creating a simulated AC sine-wave output at variable frequency, a VFD allows motors to run at any speed within a wide range, rather than just full-speed or off. This capability has made VFDs indispensable for modern motor control, offering dramatic improvements in energy efficiency, process precision, and equipment longevity.
- Why use a VFD? In traditional fixed-speed motor systems, excess output is often throttled mechanically (for example, using valves on pumps or dampers on fans), which wastes energy. A VFD eliminates this waste by matching motor speed to the actual load demand, so the motor uses only the power needed for the task.
- **The benefits are significant:** for instance, slowing a centrifugal pump or fan by just 20% can cut its energy consumption by roughly 50%, thanks to the cube-law relationship between speed and power **2**.
- **3.** In practical terms, facilities that retrofit VFDs on pumps, fans, and conveyors frequently see 30–50% reductions in energy use, translating to substantially lower utility bills [2](#).
- Beyond energy savings, VFDs provide gentle soft-starting and stopping, improved process control, and reduced mechanical stress on machines – all of which we will explore in detail below.
- In this comprehensive guide, we will dive into how VFDs work, their technical specifications and industry standards, and the real-world applications that illustrate their value. We will also compare features from multiple leading manufacturers – including ABB, Yaskawa, Eaton, Lenze, Hitachi, and others – to highlight the state-of-

the-art in VFD technology. Throughout, we will cite manufacturer documentation, industry standards, and research to ensure technical accuracy.

- Finally, we'll review case studies demonstrating the dramatic improvements in efficiency and performance that VFDs can deliver in industrial settings.

How Variable Frequency Drives Work

- A VFD is essentially a power conversion device with three main stages: a rectifier, a DC link, and an inverter. The rectifier (often a diode bridge or active AC-DC converter) takes incoming AC line power and converts it to DC. This DC link stage smooths and filters the power (usually with capacitors and sometimes inductors) to provide a stable DC supply. Finally, the inverter stage uses high-speed switching devices (IGBT transistors in modern drives) to create a pulse-width modulated (PWM) waveform that imitates a sinusoidal AC output at the desired frequency and voltage [4 5](#) . By controlling the switching pattern, the VFD outputs a variable frequency (and corresponding voltage) that can range from near-zero up to a set maximum (often 50–60 Hz base frequency and higher). For example, a microdrive like the Yaskawa GA500 can output frequencies up to 590 Hz for special applications [6](#).
- Voltage and frequency control: Simply varying the frequency to the motor is not enough – the drive must also adjust voltage in proportion to maintain an adequate magnetising current in the motor. VFDs typically follow a V/Hz profile (constant ratio) at least up to the base speed. At lower frequencies, the drive reduces the voltage to avoid saturating the motor (since a longer AC period would otherwise put more energy into the windings) [7](#).
- Most VFDs offer a selectable V/Hz pattern or more advanced control modes (discussed below) to optimise torque across the speed range.
Control modes: Early VFDs used simple open-loop V/Hz control. Modern drives often implement advanced algorithms like sensorless vector control or even field-oriented control and Direct Torque Control (DTC). These allow the drive to hold precise speed or torque without a feedback encoder, by internally estimating the motor's magnetic state.
- For example, ABB's high-end drives use DTC to achieve near-instantaneous torque response and full torque at zero speed (useful for cranes, mills, etc.), all without encoders [8](#).

- Many drives also support closed-loop control with encoder feedback for applications requiring extremely tight speed regulation (e.g. elevators or coordinated multi-motor systems).
- **Power and torque characteristics:** The motor's synchronous speed is proportional to supply frequency (per the formula $N_s = 120f/p$ for induction motors). Thus, by lowering frequency, a VFD directly reduces motor speed. Torque capability, however, depends on maintaining magnetisation – hence the need for proper V/Hz control or vector control. Typically, a good VFD can maintain rated torque from zero speed (with vector control) up to base speed, and above base speed, the motor enters a constant-power region as voltage can no longer increase (field weakening) [9](#).
- **VFDs usually allow some overload capacity:** common designs have a “heavy duty” rating (e.g. 150% of rated current for 60 seconds) and a “normal duty” rating (maybe 110% for 60 seconds) – users select the appropriate size based on whether high overload for acceleration or peak loads is needed [10](#).
- This overload capability is crucial for applications like crushers or conveyors with intermittent heavy loads.
- **Efficiency and losses:** Modern IGBT-based drives are highly efficient – typically around 95–98% efficient at full load. Some energy is lost as heat in the power electronics.
- Drives often include cooling fans and heatsinks, and larger units may be liquid-cooled. It's worth noting that the overall system efficiency can improve with a VFD despite the drive's losses, because running a motor at partial speed (with reduced losses in the load and motor) far outweighs the few per cent losses in the drive.
- **However, users should be aware of certain side effects of PWM inverters:** the fast switching can introduce voltage spikes and high-frequency harmonics that stress motor insulation and bearings [5 11](#).
- We will discuss the mitigation of these issues (filters, “inverter-duty” motors, etc.) in the standards section.

Key Benefits of Using VFDs

- Variable frequency drives offer numerous benefits across energy savings, equipment protection, and process improvement.
- **Energy Savings:** By far the biggest advantage of VFDs is improved energy efficiency.

For centrifugal loads (pumps, fans, blowers), the power required drops roughly with the cube of speed as given by the affinity laws [3](#).

- In practical terms, a small reduction in speed yields a large reduction in power: e.g. running a fan at 80% speed might consume only ~50% of the power; at 50% speed, power might drop to ~12.5% (an 87% reduction) [3](#).
- This makes VFDs extremely effective for HVAC systems, pumping stations, and any process with variable flow demand.
- **Many facilities have documented huge savings:** for example, ABB reported that using an ACS580 VFD on a variable-torque pump load reduced annual energy costs by 48% while also extending pump seal life by two years [12](#).
- In Section 5, we present additional case studies, including a municipal plant retrofit that cut energy use by 30% and a commercial HVAC project saving over \$150,000 a year by adding VFDs.
- **Soft Starting & Reduced Mechanical Stress:** When an AC motor starts across-the-line (direct on full voltage), it inrushes 6 to 8 times its rated current and produces a torque spike [13](#) [14](#).
- This abrupt start stresses gears, belts, couplings, and the motor itself, often causing voltage dips and mechanical wear.
- A VFD, in contrast, ramps up the motor speed gradually (adjustable accel/decel ramps), eliminating the high startup current and mechanical shock. The result is gentler starts and stops, which extend the life of machinery.
- For example, using VFDs can reduce water hammer in pump systems and minimise pressure surges.
- VFDs also offer controlled deceleration and braking functions (dynamic braking resistors or regenerative braking) to slow down loads without jarring stops [13](#).
- An added benefit is the ability to reduce peak demand charges by avoiding large instantaneous power draws on startup – a crucial factor in many industrial electric bills [15](#).
- **Improved Process Control:** VFDs allow infinitely variable speed control, giving operators and automation systems very precise command over process variables. Instead of coarse on/off or valve control, a VFD can continuously modulate motor speed to maintain a setpoint (flow rate, pressure, temperature, etc.). Most drives include a built-in PID controller mode for this purpose. For instance, a pump VFD can be set to maintain a constant discharge pressure – it will automatically speed up or

slow down as demand changes, eliminating the need for a separate pressure regulator valve [16](#). The result is better product quality and process consistency, as conditions can be finely tuned.

- In manufacturing, VFDs improve things like tension control in web handling, or ramp-up profiles for mixers to avoid splashing. In HVAC, they smoothly adjust fan speeds to meet temperature setpoints.
- Overall, VFDs empower a much higher degree of automation and optimisation in industrial processes.
- **Reduced Maintenance & Downtime:** By running motors at optimal speeds and avoiding the excessive heat and stress of full-speed operation, equipment lasts longer. Bearings and seals experience less wear when speeds are reduced; soft starts avoid sudden mechanical strain that can cause failures [17](#). Many VFDs also have built-in diagnostic and protective features that can detect issues early – for example, monitoring for overcurrent, overvoltage, phase loss, or motor overtemperature.
- They can trip to prevent damage or signal an alarm for maintenance. Modern drives from major manufacturers often include predictive maintenance functions: e.g., ABB's drives can display cooling fan run-time or capacitor health so that technicians know when to service those components [18](#). All of this means fewer unplanned shutdowns.
- **One real-world example:** a pulp & paper plant replaced 20 ageing motor drives with modern VFDs and saw unplanned drive failures drop by 76%, dramatically improving uptime [19 20](#).
- In another case, a bottling facility kept a pre-configured spare VFD on hand; when a production line drive failed, they swapped in the spare within minutes, avoiding an estimated \$42,000 in downtime losses [21 22](#).
- **Power Factor and Electrical Benefits:** VFDs typically use a front-end rectifier that draws current in phase with voltage (especially with active front ends), so the displacement power factor is high (near 1.0) at full load. However, standard drives do introduce current harmonics, which is a trade-off (addressed later). Still, using VFDs can mitigate the need for separate soft-starters or phase correction capacitors in some systems.
- Additionally, because VFDs reduce overall energy consumption, they can allow downsizing of backup generators or transformers. For instance, in a case where a municipality added VFDs, they found they could use a smaller standby generator since the VFDs limited inrush currents and reduced peak demand [23](#).

- VFDs are also a key enabler for energy management and even regenerative braking – some drives can feed energy back into the supply, further improving efficiency in applications with frequent braking (e.g. elevators, cranes).
- In summary, the VFD's ability to closely match motor output to actual needs yields significant energy and maintenance savings, while the electronic control opens up a world of flexibility in how processes are run.

Technical Specifications and Standards

- When selecting or applying a VFD, it's important to understand key technical specifications and how they relate to industry standards and application requirements.
- **Voltage and Power Ratings:** Low-voltage VFDs (for 3-phase systems) commonly accommodate input supply in ranges like 200–240 V, 380–480 V, or 575–690 V AC. A given drive model will be rated for a certain supply voltage range (e.g., “380–480 V $\pm 10\%$ ”). Output voltage to the motor is typically up to the line voltage (cannot exceed it without an active boost converter), and the output frequency range often goes from 0 Hz up to 50/60 Hz or higher. Many drives support output frequencies up to 120 Hz or even 400+ Hz, enabling overspeed in applications or use with high-frequency spindles [6](#). Power (horsepower or kW) ratings range widely: microdrives cover fractional HP up to a few tens of HP, while industrial drives like ABB's ACS880 series scale to thousands of HP with modular designs [24](#). Always size a drive for the motor's full-load current rather than HP alone, accounting for overload if needed.
- **Overload Duty:** As mentioned, VFDs have different current overload capabilities. A Heavy/High Duty (HD) rating typically allows ~150% of rated current for 60 seconds (and maybe 200% for a short 2-3 second interval), whereas a Normal Duty (ND) or light duty might allow ~110-120% for 60 seconds [10](#). The HD rating is used when the load is high-torque or has frequent acceleration (e.g. hoists, crushers), whereas ND assumes a more steady load or variable-torque load (like fans). Manufacturers list both; for example, an Eaton PowerXL DG1 drive might be labelled “50 HP ND / 40 HP HD” – meaning if you need heavy overload, treat it as a 40 HP drive. Always check these specs against your motor's requirements and the application's load profile.
- **Switching Frequency and Motor Compatibility:** VFDs use high-frequency PWM switching to create the AC output. Typical carrier frequencies are 2–15 kHz, often user-adjustable (higher can give quieter motor operation and smoother torque, but at

the expense of more heat losses in the drive). The fast voltage rise times (dv/dt) of PWM pulses can cause voltage spikes at the motor, especially if long cables are used, due to transmission line effects and wave reflection [25](#).

- Standard motors not designed for inverter use can suffer insulation damage if these spikes exceed their insulation rating.
- Industry standards like NEMA MG1 Part 31 address this: for 460 V motors, MG1 Part 31 requires the motor insulation to withstand spikes of 1600 V with rise times of 0.1 microseconds [26](#).
- Motors meeting “inverter-duty” ratings will comply with these specs (often having corona-resistant wire, etc.). If a motor is older or cable runs are very long, it’s prudent to use output filters or dV/dt filters on the VFD to protect the motor [27](#).
- Also, high switching frequencies induce shaft voltages that can cause bearing EDM pitting; shaft grounding rings or insulated bearings are recommended for larger motors to prevent premature bearing wear [11](#).
- Input Harmonics and IEEE 519: A drawback of VFD rectifiers (especially the common 6-pulse diode type) is that they draw non-linear current, injecting harmonics back into the supply.
- Excessive current harmonic distortion can overheat transformers and disturb other equipment. IEEE 519 is the key guideline for harmonic limits in power systems (e.g. it might require <5% total harmonic distortion (THD) at the point of common coupling for certain systems). Drive manufacturers address harmonics in several ways: many standard drives include DC link chokes or AC line reactors that significantly cut down harmonics (a “swinging choke” design in ABB’s ACS580 drives, for example, can reduce harmonics by ~35–40%, helping meet IEEE 519 limits [24](#) [28](#)). Some drives use 12-pulse or 18-pulse rectifier configurations or active front-end (AFE) converters to achieve much lower THD – these are often specified in sensitive installations. For most general-purpose drives, adding an input line reactor or using the built-in choke is enough to satisfy typical utility requirements. If a facility has strict power quality standards or generator-fed drives, an AFE drive or external harmonic filter might be warranted to comply with IEEE 519.
- **Safety Functions (STO and more):** Modern VFDs often integrate functional safety features, most commonly Safe Torque Off (STO). STO is a circuit that, when activated, immediately disables drive output (removing power to the motor) without completely powering down the drive. This facilitates a safety stop that meets standards like IEC

61800-5-2 and ISO 13849. Many drives have STO rated to SIL 2 or SIL 3 (Safety Integrity Level) and Performance Level e (PL e). For example, the Yaskawa GA500 microdrive includes dual-channel STO that meets SIL3/PLe requirements [29](#), as does ABB's entire ACS family (ACS180/380/580/880 all have STO to SIL3 built-in) [30](#). This means that machine builders can often eliminate external safety contactors, simplifying panel design and improving safety integration. Other safety options on high-end drives might include safe brake control, safe stop ramps (SS1), or even integrated safety controllers, but STO is by far the most common and important for most use cases.

Environmental Ratings and Filters: VFD units come in various enclosure ratings. A basic open chassis might be IP20 or NEMA1 (indoor, protected), whereas sealed units for harsher environments can be IP54/55 (dust tight, water resistant) or NEMA 4X (watertight, outdoor use). Ensure the chosen drive enclosure suits the installation – e.g., an HVAC rooftop unit might need a NEMA 3R or 4 type enclosure. Thermal management is critical: most drives are specified for operation up to 40°C ambient without derating, and many can do 50°C with some derate or with special high-temperature ratings. For instance, Eaton's PowerXL drives are designed with cooling isolation that allows operation at 50°C without performance loss [31](#) [32](#).

- Always check the datasheet to see if the drive will be in a hot room or sunlight. Also consider altitude (above ~1000m, cooling is less effective), and provide adequate cooling air clearance as recommended.
- Many drives include EMC filters (RF interference suppression) built-in or as options to meet CE (European) EMC directives. For installations in the EU or where radio interference could affect nearby equipment, use of these filters is recommended to comply with standards like IEC 61800-3 for EMC.
- **Motor Types and Special Features:** While standard VFDs are associated with AC induction motors, many can also control advanced motor types. Permanent Magnet (PM) AC motors and synchronous reluctance motors offer higher efficiencies; leading drive brands have incorporated control algorithms for these.
- For example, Yaskawa's latest drives can auto-tune and run interior PM or surface PM motors in open-loop, and ABB offers packages combining their drives with SynRM (synchronous reluctance) motors to achieve IE5 efficiency class systems [33](#) [34](#).
- Other notable features to look for: built-in PID controllers for process control, "droop" control for load sharing between multiple motors, flying start (ability to catch a

- spinning motor and ramp it down or up smoothly), DC injection braking to hold a motor at a standstill, and application macros (pre-configured parameter sets for common setups like fans, pumps, conveyors). Communication connectivity is also key – most industrial VFDs support fieldbus modules or onboard protocols such as Modbus RTU,
- Ethernet/IP, PROFINET, CANopen, BACnet, etc., making it easy to integrate the drive into a plant's control system.
 - **Check the drive's I/O as well:** typically, you get several programmable digital inputs, analogue inputs, relay outputs, etc., which can often eliminate external PLC logic for small tasks.
 - **Compliance and Certification:** VFDs should carry relevant certifications for the regions they are used in. UL and CSA listings are important in North America for safety; CE marking in Europe indicates compliance with low-voltage and EMC directives. Many drives also comply with IEC 61800-5-1 (general safety requirements for adjustable speed drive systems). If used in hazardous (classified) locations such as gas or dust environments, special drive enclosures or purging might be required – check for any ATEX or UL Zone ratings if applicable.
 - To summarise, proper drive selection involves matching these technical specs to the motor and application: supply and motor voltage, current and overload needs, environmental conditions, and any special functionality needed (EMC, safety, communications).
 - Additionally, adherence to standards like NEMA MG1 and IEEE 519 ensures that both the motor and the supply line will have long, reliable service with the VFD in place.

Leading VFD Manufacturers and Notable Drive Series

- The VFD market is well-established, with several major manufacturers producing high-quality drives. Each has its strengths and unique technologies. Here we highlight a few top brands and examples of their drive series, to provide a sense of the landscape:
- **ABB:** ABB is one of the global leaders in drives, offering the all-compatible ACS series for low voltage and a range of medium voltage drives. ABB drives are known for their advanced control (they introduced Direct Torque Control in the 1990s) and broad power range. For example, the ACS880 series (industrial drives) covers 0.55 kW up to 6000 kW in low voltage, with options for regenerative capability and ultra-low harmonic

versions [24 35](#).

- The general-purpose ACS580 is a popular model for fan/pump and general automation, featuring built-in swinging chokes for harmonic reduction and user-friendly energy saving features (the ACS580 drive can even display energy saved in kWh and estimated cost or CO₂ reduction on its panel) [36 37](#).
- ABB emphasises consistency across its range – the user interface and programming of a small ACS180 is similar to a large ACS880, which simplifies training [38](#).
- **Another note:** ABB includes Safe Torque Off (SIL3) as standard on virtually all its models [30](#).
- In terms of support, ABB has a global service network and typically offers extensive documentation and software tools (e.g., DriveSize for selection, DriveComposer for configuration). ABB drives are often praised for robust hardware and the ability to handle tough industrial environments; they are used in industries from water/wastewater to metals and marine. Cost-wise, ABB is generally mid-range – typically more affordable than Rockwell/Allen-Bradley, and competitive with other European brands. Many users consider ABB drives a “safe choice” given their reliability and support.
- **Yaskawa:** Hailing from Japan, Yaskawa Electric is frequently cited as the gold standard for VFD reliability. Yaskawa is the world’s largest manufacturer of AC drives by volume.
- Their drives have an extraordinary track record for longevity – published quality data shows a final factory test failure rate of only 0.01%, and field failure rates around 0.006% (just 62 units per million in service), corresponding to a mean time between failure (MTBF) exceeding 28 years [39 40](#). This is achieved through rigorous design and 100% testing of every unit. Yaskawa is also famous for its user-friendly design. Current product lines include the GA500 microdrive (low horsepower, up to ~30 HP or 18.5 kW) and the GA800 (for larger motors up to -600 HP or 500 kW), which replaced the older V1000/A1000 series [41 42](#). Yaskawa drives typically come standard with features that simplify use: for example, the GA500 offers an embedded setup wizard, Bluetooth connectivity via an optional keypad, and a mobile app for programming. They also support all common fieldbuses (Modbus is built-in, and option cards add Ethernet/IP, PROFINET, etc.) [43 44](#). Performance-wise, Yaskawa drives have excellent motor control, with high starting torque and precise speed hold even in open-loop vector mode [45 46](#). They can run both induction and permanent magnet motors

(the GA800 can auto-tune PM motors in sensorless mode).

- Notably, Yaskawa introduced a special matrix converter drive (U1000) that can feed power back to the grid with low harmonics, eliminating the need for separate regenerative units or braking resistors [47](#).
- While a niche product, it showcases Yaskawa's innovation. In heavy industries like mining, metal, and oil & gas, Yaskawa drives are valued for being nearly "indestructible" in harsh conditions [48](#).
- Despite their high quality, Yaskawa's pricing is quite competitive – usually on par with or slightly lower than ABB, and lower total cost of ownership over time due to their longevity [49](#).
- **Eaton (Cutler-Hammer):** Eaton is a major player, especially in North America, offering the PowerL series, among others. Eaton's drives originated from acquisitions (such as Powerware and parts of the former Danfoss/Vacon designs).
- Their DG1 general-purpose VFD covers ~1-500 HP, with features like active energy control (which can autotune energy savings at partial loads) and dual ratings for normal/heavy duty [50 51](#).
- For smaller motors, Eaton has the DM1 micro drives.
- Eaton also specifically targets HVAC with products like the H-Max series and legacy HVX9000 drives, which come with built-in PID controllers and HVAC-friendly interfaces (hand-off-auto switches, etc.) [52 53](#).
- While Eaton's brand in drives isn't as globally recognised as ABB or Yaskawa, they are known for solid performance and very good pricing. Many Eaton drives are indeed re-badged Danfoss or share design DNA with former Vacon drives, which are proven designs. Users often comment that Eaton drives have good documentation and software, and they particularly appreciate Eaton's extensive distributor network – if you need a drive quickly in the US, Eaton is often readily available locally [54 55](#).
- Eaton drives support common protocols (EtherNet/IP, BACnet, Modbus, etc.), typically via add-on modules. In summary, Eaton VFDs represent a cost-effective alternative that doesn't sacrifice much in capability. They may not have some of the ultra-high-end features, but they meet the needs of most applications at a lower price point, and with the backing of a large electrical equipment company.
- **Lenze (AC Tech):** Lenze is a German manufacturer that, through its AC Tech division in the USA, has a strong presence, particularly in small and mid-size drives. Lenze drives are known for their compact size and simplicity. A popular legacy product was

the SMVector series (AC Tech), which was often used as a drop-in replacement for smaller Rockwell PowerFlex drives. Now Lenze's flagship is the i500 series, a modular drive system from 0.33 HP up to -60 HP (0.25-45 kW) [56 57](#).

- The i500 is designed with a slim form factor to save panel space and has plug-in modules for communications and I/O, so OEMs can tailor the cost by only adding what they need [58 59](#).
- Lenze drives handle standard V/Hz and vector control reliably for general industry needs.
- They might not have every advanced feature of a high-end drive (for example, fewer custom functions or advanced autotuning compared to Yaskawa), but for standard applications, they are very easy to use and cost-effective.
- One caveat often noted by users is that Lenze's documentation, while thorough, can be a bit hard to navigate [60](#).
- However, once set up, the drives are stable and perform well. Lenze has a strong niche in packaging machinery and machine tools, particularly in Europe.
- Their drives can integrate in automation systems via CANopen (commonly used in Europe), and options for EtherNet/ IP, EtherCAT, PROFINET, etc., are available to interface with Allen-Bradley or Siemens PLCs [61 62](#).
- Given their German engineering background, Lenze's hardware quality is solid, and they aggressively price their smaller drives – often significantly cheaper than Allen-Bradley for similar power.
- This makes them attractive for OEMs building cost-sensitive equipment.
- **Hitachi:** Hitachi has produced drives for decades and is well-regarded for offering robust, no-frills VFDs at a good price. The Hitachi WJ200 series (up to ~20 HP) gained popularity as a compact general-purpose drive, known as a “workhorse” that includes sensorless vector capability and easy setup. Hitachi also offers larger drives like the SJ series (e.g., SJ700, and the newer SJ-P1), which can handle higher horsepower (the SJ700 went up to -500 HP at 480V) and provide more advanced vector control with features like 200% starting torque and even simple built-in PLC logic (Hitachi's EzSQ programming) [63 64](#).
- A key selling point for Hitachi is that many models come with built-in EMC filters and functional options included, rather than as expensive add-ons.
- They also generally support both heavy and normal duty ratings. While Hitachi's drives in the North American market are somewhat lesser-known compared to ABB or

Yaskawa, those who use them often comment on their reliability and value for money.

- For example, a 10 HP Hitachi drive might cost significantly less (sometimes 20-30% less) than a comparable Rockwell PowerFlex, yet deliver similar performance in many standard applications.
- Hitachi's documentation and parameter naming can be a bit different (since originally targeted at Asian/European markets), but once acquainted, integration is straightforward. Hitachi has authorised distributors and some service centres in the U.S., and companies like Precision Electric often support Hitachi drives for repairs or replacements. In summary, Hitachi VFDs are a strong option, especially for small-to-medium power ranges where budget is tight but solid performance is needed.
- **Rockwell Automation (Allen-Bradley):** No comparison would be complete without mentioning Allen-Bradley's PowerFlex drives, since they are prevalent in North America. Rockwell's PowerFlex line (70/700, 750 series, 523/525, etc.) is deeply integrated into Allen-Bradley PLC systems. They excel in applications where tight integration with Rockwell controllers is desired (Add-On Profiles in Studio 5000 make drive parameters very accessible, etc.).
- However, PowerFlex drives are typically more expensive than equivalent drives from other brands – partly due to Rockwell's pricing structure and support model. Many plants that are standardised on Allen-Bradley use PowerFlex by default for the commonality. Technically, PowerFlex drives are very capable (the 755, for instance, has options for almost any feature: safety, regen units, harmonics filters, etc.). But outside of a Rockwell-centric plant, alternatives from ABB, Yaskawa, etc., often provide better value. As illustrated in a Precision Electric analysis, switching from Allen-Bradley to other brands can save 20-30% in upfront cost with no sacrifice in quality [65](#) [66](#).
- Many facilities choose to retrofit older AB drives with, say, an ABB or Eaton when budgets are constrained, especially once the original warranty/support is no longer a concern.
- **Others:** There are many other reputable drive makers. Danfoss, for instance, is known for HVAC and refrigeration drives (their VLT series) and high-performance industrial drives (Danfoss also acquired Vacon).
- Schneider Electric (Telemecanique) offers the Altivar series. WEG (from Brazil) produces a wide range of drives often paired with their motors.
- Mitsubishi, Fuji Electric, Delta Electronics, and KEB are also players with niche

followings or regional presence.

- Each of these has its particular strengths (for example, Danfoss drives are very common in HVAC pumping stations due to excellent flow control features and inbuilt PID, Mitsubishi is known for compact servo drives and high-speed spindle drives, etc.).
- For brevity, we focus on the major brands above, but it's always wise to evaluate local support and specific feature needs – sometimes a local brand with good service can be the best choice for a given plant.
- In conclusion, the VFD market has matured such that quality and performance are high across all top brands.
- **Differences come in nuances:** one brand might excel in high overload applications, another in user- user-friendliness, another in cost or specific industry solutions.
- When choosing, consider the application's demands, your team's familiarity, and the availability of support.
- All the manufacturers discussed provide extensive catalogues and selection guides to help pick the right drive for the job.

Real-World Applications and Case Studies

- To cement the understanding of VFD benefits, let's examine a few real-world case studies from different industries.
- These examples showcase how implementing variable frequency drives can lead to measurable improvements in energy usage, performance, and reliability.

Case Study 1: Municipal Water Pumping Energy Savings

- A city wastewater treatment facility (City of Columbus, Ohio) undertook a project to improve efficiency at its influent pumping station by installing VFDs [67 68](#).
- Originally, the station had constant-speed pumps and used valve throttling to control flow – a very inefficient method.
- In 2011, the city replaced three of five large pumps with new variable-speed pumps driven by VFDs (the other two old pumps were kept for occasional backup use) [67](#).
- The VFDs allowed the pump speeds to be modulated to match incoming flow more closely and also enabled raising the wet-well water level setpoint (reducing static lift).
- **Results:** After the retrofit, the specific energy (electricity per volume pumped)

dropped from 259 kWh per million gallons to 179 kWh/MG – a 30% reduction in energy usage for pumping the same volume of water [68](#).

- In addition, because the VFDs act as soft starters, the facility saw a significant drop in peak demand.
- The peak power drawn by the pumps went from 60 kW (with across-the-line starting) to just 30 kW with the VFDs – a 50% reduction in peak power demand [69](#).
- This is extremely important, as utilities often charge high demand fees; cutting the peak in half can yield thousands of dollars in additional savings annually.
- The city also extended VFD control to its aeration blowers in a later project, resulting in about 26% energy cost reduction for aeration, demonstrating VFD's effectiveness in multiple processes [70](#). Overall, the case study highlights how a relatively straightforward upgrade (installing VFDs and modern controls) can capture 30+% energy savings in water infrastructure – a sector where pumps and blowers typically run 24/7 and energy costs are a major part of operating expenses.
- The success in Columbus mirrors many other municipal and industrial water systems: by tailoring motor speed to the actual demand, enormous waste is eliminated.
- (Notably, this project also allowed the city to avoid upsizing its emergency generator, since the VFDs limited inrush currents, illustrating another side benefit [23](#).)

Case Study 2: Commercial HVAC and Building Retrofits

- Large commercial buildings – such as office towers, hospitals, and shopping centres – often have dozens of motors for fans, pumps, and chillers. Retrofitting these with VFDs has shown dramatic energy and cost savings.
- A well-documented example comes from a multi-year retrofit of a high-rise building's HVAC system.
- Over 2011-2013, the facility progressively installed VFDs on various equipment: first on chilled water pumps, then on cooling tower fans, air handler fans, etc. By the end, roughly 150 motors from 7.5 HP up to 250 HP were outfitted with VFDs [71 72](#).
- **Results:** The building operators tracked energy use and found an annual electricity consumption reduction of 32% after all VFDs were in place (the building's usage dropped from -65 million kWh/year to 43 million kWh) [73](#).
- Peak demand, which had been about 16-17 MW, fell to around 10 MW (~ 33% reduction) after the retrofit [73](#). In financial terms, the project saved over 1\$1.1 million

per year in energy costs [74 75](#).

- The payback on the VFD investments was well under 3 years just from energy savings alone. Additional benefits included more stable indoor temperatures (since fan speeds adjust continuously rather than on/off cycling) and less mechanical stress on the HVAC equipment (soft starts reduced belt and bearing wear). This case is emblematic of thousands of VFD retrofits across commercial facilities – whether it’s a retail chain like JPenney installing drives on rooftop units and saving \$150k+ annually [76 77](#), or a university campus upgrading chiller pumps and air handlers. The combination of utility incentives, energy savings, and maintenance reduction makes VFDs very attractive in the HVAC domain.
- Many utilities offer rebates for VFD installations because they help reduce peak grid load.
- Overall, the investment in VFDs is often one of the best “low-hanging fruit” energy efficiency measures in large buildings [78](#).

Case Study 3: Industrial Manufacturing – Reliability and Uptime

- Energy savings often steal the spotlight, but VFDs also profoundly affect reliability and process uptime.
- Consider the example of a Midwestern pulp & paper mill that was experiencing frequent failures of older drive units on critical production motors. The drives in question were legacy ABB ACS500 series, well past their prime, controlling things like large rollers and pumps. The plant partnered with a service provider (Precision Electric) to proactively replace 20 of these drives during a scheduled shutdown, upgrading to new ABB ACS580 models with modern diagnostics [19 79](#).
- They also kept the old drives as spares and implemented a monitoring routine.
- **Results:** In the year following the upgrade, unplanned drive failures dropped by 76% compared to prior years [80 81](#).
- The few faults that did occur were handled quickly because the plant had spare drives ready to swap in (a strategy enabled by standardising on one drive family and keeping the old units as backups).
- This directly translated to improved production uptime and prevented costly downtime that previously plagued the mill. In heavy industries, a single drive failure can stop an entire production line, costing tens of thousands of dollars per hour, so this

improvement was extremely valuable to the mill's bottom line.

- Moreover, the new drive diagnostics gave maintenance staff better insight (e.g., warning of over-temperature or power issues), so they could address underlying causes like cooling fan failures or input power quality before they led to drive trips.
- Another industrial example comes from a beverage bottling plant that was highly sensitive to downtime – they faced global supply chain delays for parts, so a failed drive could halt production for days if no replacement was on hand.
- The plant installed a spare Yaskawa GA500 drive in parallel (wired and configured) for a critical bottling line motor, such that if the primary drive failed, they could switch cables to the spare in minutes [21 82](#).
- Indeed, a failure did occur, but the maintenance team swapped to the spare drive immediately and kept the line running. The failed unit was sent for repair, but no production was lost.
- It was estimated that this quick recovery avoided around 1\$42,000 in lost output for that incident [21](#).
- While this example is more about smart redundancy than the VFD itself, it underlines that using standard, readily available VFD models and having spares can be a crucial reliability strategy.
- And modern drives' ability to have parameters cloned (e.g. via keypad copy or using a laptop) makes deploying a spare very straightforward – one can pre-load the settings so the new drive behaves exactly like the old one.

Case Study 4: Regenerative Applications and Unique Benefits

- VFDs also enable energy regeneration and improved control in dynamic applications. A notable case is in overhead cranes for a manufacturing plant. Traditionally, crane hoists dissipate braking energy as heat through resistor banks when lowering loads.
- By using regenerative VFDs (with active front ends) on the hoist motors, the plant was able to feed that energy back into the facility's power system. One crane builder reported that using ABB ACS880 regenerative drives not only saved energy but also reduced the heat load in the building, which in turn lowered HVAC costs by about 30% for the crane bay area (since the braking resistors were no longer dumping heat) [12 83](#).
- This is a double benefit – energy that would be wasted as heat is reused, and the

ambient cooling load drops. Additionally, the regenerative drives provided very precise speed control and safety interlocks, improving the positioning accuracy of the cranes and the safety of operations (smooth handling of heavy loads with no jolts).

- In transportation, a similar principle is seen: electric trains and elevators use regenerative drives to send power back when slowing down, significantly improving overall efficiency.
- These are specialised VFD applications, but are growing more common as everyone looks to recycle energy.
- Finally, consider remote pumping operations (like oil pipeline booster pumps or irrigation systems in agriculture).
- VFDs not only save energy but can dramatically improve operability: a VFD can ramp a pump up slowly to avoid water hammer in long pipelines, and can adjust speed to match varying supply (for example, if a well's water level changes).
- They also reduce the need for maintenance trips because many VFDs support remote monitoring – pumping stations can be monitored and even controlled over SCADA systems.
- The reliability improvement (fewer abrupt pump seizures, less stress on couplings) means less frequent repairs.
- This kind of operational flexibility is hard to quantify in dollars but often very valuable - processes can be fine-tuned or adapted in real-time, something simply not possible with fixed-speed motors.
- These case studies underscore that VFDs are not just theoretical energy savers; they deliver tangible results across industries.
- Whether the goal is cutting energy consumption, stabilising a process, or avoiding downtime, real-world data consistently shows VFDs paying for themselves quickly.
- It's also evident that success involves considering the whole system – using VFDs in conjunction with proper controls, possibly upgrading motors to inverter-duty if needed, training staff on the new capabilities, and sometimes implementing complementary measures (like keeping spares or using regen units) for maximum benefit.
- When done right, VFD integration is a win-win: lower costs and better performance.

Best Practices for VFD Implementation

- When deploying VFDs, a few best practices can ensure you get the most out of the

investment.

- **Proper Sizing and Selection:** Use manufacturer tools or consult application engineers to pick the right drive for your motor and load. Ensure the drive's current rating (especially heavy-duty current) comfortably covers the motor's requirements and any overload demands. If the environment is harsh (high temperature, dust, altitude, factor in derating or choose a drive with the appropriate enclosure and cooling. Also, consider if you need options like filters or network communication modules upfront.
- **Motor and Cable Considerations:** If you are adding a VFD to an existing motor, verify the motor is in good condition and ideally "inverter-duty" rated per NEMA MG1 Part 31 (for medium-voltage motors or very long cable runs, also check peak voltage specs carefully) [26](#).
- Use shielded motor cables and keep cable lengths within the drive's recommendations. If long cables (>50m or so) are unavoidable, consider adding a dVdt output filter or sine wave filter to protect the motor insulation and reduce EMI.
- Don't forget to provide proper grounding – both the drive and motor should be grounded as per the manual to ensure safe operation and minimise electrical noise issues.
- **Harmonic Mitigation:** In facilities with a large number of drives or sensitive equipment, plan for input harmonic mitigation.
- This could be as simple as line reactors on each drive or a passive harmonic filter on groups of drives, or, for critical cases, active harmonic filters or multi-pulse drives.
- IEEE 519 guidelines can be met with relatively straightforward measures in most cases, [84 85](#).
- Also, to avoid nuisance trips or generator issues, use drives with DC chokes or add reactors when drives are fed from standby generators – this smooths the current waveform and helps the generator handle the nonlinear load.
- **Programming and Tuning:** Take advantage of the VFD's programmability. Set appropriate accel/ decel times to balance between quick response and avoiding mechanical stress (e.g., don't set acceleration to 0.1s unless needed; a few seconds ramp is easier on equipment). Use the built-in PID loop if you want the drive to maintain a process variable – but do tune the PID gains, or use auto-tuning features if available, to get stable control. Enable any energy optimisation or "sleep" functions for pumps/fans (some drives can sense when flow is minimal and stop the motor to save

energy, then restart when needed). Also configure the protective features: motor overload protection, stall prevention, torque limits, etc., to suit your application.

- Modern drives often let you set custom fault thresholds or alarms – for example, you could program an alert if a fan is running at 100% speed (maxed out), which might indicate a filter is clogged downstream, causing high load.
- **Safety and Integration:** If using the drive's Safe Torque Off, be sure to integrate it properly into your safety circuits (typically, it involves two-channel wiring to the STO terminals and periodic testing).
- This can eliminate the need for a contactor, but make sure to meet whatever local code or safety standard applies to your machine.
- Integrate the drive into your control system via whichever communication protocol is convenient – having networked drives can greatly simplify monitoring and control (you can adjust speeds, get feedback on current, power, temperature, etc., remotely).
- Many drives also support condition monitoring data over these interfaces.
- **Environmental and Installation Factors:** Provide adequate cooling air around drives, and if in a cabinet, consider using forced ventilation or air conditioning for larger drives that emit significant heat.
- Keep the drive and motor leads separate from sensitive signal cables to minimise electromagnetic interference (EMI); follow the wiring practices recommended (e.g., using conduit or shielding and proper grounding at one end of the shield).
- If multiple drives are in one panel, check if you need to de-rate due to grouping (some compact drives can be mounted side-by-side with no clearance, others may need spacing). For drives in dusty or corrosive areas, use appropriate enclosures and possibly conformal-coated circuit boards (many industrial drives come with PCR coating by default for protection). Regularly clean any cooling fans and heat sink fins – clogged filters or failed fans are a common cause of drive overheating.
- **Maintenance:** VFDs are largely maintenance-free, but they do have some consumable components.
- The cooling fan(s) often have a lifespan of maybe 3-5 years of continuous operation – plan to inspect or replace them on that interval, especially for larger drives.
- The DC bus capacitors gradually dry out over the years; a typical design life is ~7-10 years at full load/full temp operation [86](#).
- Some drives, as noted earlier, can display capacitor health or give a “capacitor reform” alarm. It's a good practice to proactively replace capacitors in critical drives at maybe

the 10-year mark if uptime is crucial (or keep a spare drive ready to swap).

- Maintaining a log of drive fault codes and performance can help predict issues – for instance, repeated under-voltage trips might indicate an upstream power problem or loose connection.
- **Training:** Ensure the maintenance and operations personnel are trained on the new drives. They should know how to start/stop/reset faults from the panel, interpret any alarm codes, and ideally have access to the parameter settings.
- Many issues can be resolved or prevented if technicians are comfortable navigating the drive's menus or software. Most manufacturers offer quick reference guides or even mobile apps (Yaskawa has DriveWizard Mobile, ABB has DriveTune, etc.) for easy interface. Because VFDs involve both electrical and software elements, bridging any skill gaps with training will pay off. A small investment in training can prevent improper settings or panic replacements down the line.
- By following these best practices, users can maximise the ROI of their VFD installations – capturing the full energy savings while avoiding common pitfalls that can lead to erratic performance or premature failures.

Conclusion

- Variable Frequency Drives have revolutionised the control of electric motors in industry. They embody a fusion of power electronics and digital control that yields substantial energy efficiency gains, superior process control, and gentler mechanical handling.
- From heavy industrial machinery to HVAC fans in an office, VFDs have proven their worth. In this article, we've covered how they work, what critical specs and standards to mind, and looked at concrete examples of their impact.
- The key takeaway is that a VFD is often the single most effective tool for matching motor work to actual needs, and in doing so, it removes waste and adds flexibility.
- As technologies advance, drives continue to get more efficient and smarter – with better harmonic performance, IT connectivity, and even AI-driven predictive controls on the horizon.
- Major manufacturers like ABB, Yaskawa, Eaton, Lenze, Hitachi, and others offer a rich selection of drives to fit every conceivable application.
- The competition and innovation in this field benefit end users with reliable products

that often exceed the required standards.

- When implementing VFDs, leveraging the expertise available (from manufacturer documentation to industry guidelines like NEMA and IEEE standards) ensures a smooth and successful deployment.
- For engineers and facility managers considering a VFD project, the evidence is compelling.
- Whether your goal is to slash energy costs in a pump network, improve the consistency of a production line, or extend the life of agina motor systems, variable frequency drives provide a well-proven solution.
- Just be sure to plan the integration thoughtfully – size correctly, protect the motor and drive with the right accessories, and utilise the advanced features to your advantage.
- If done correctly, you'll join the ranks of those who see not only a healthier electric bill, but also a more controllable and reliable operation.
- (References are embedded as links throughout this article for further reading on specific points.)

References

1. **Ruekert & Mielke (2021)** – “Energy Savings and Other Benefits of Variable Frequency Drives: City of Columbus Case Study.” – Describes the Columbus WWTP pump VFD retrofit with 30% energy reduction and 50% demand reduction, plus VFD fundamentals for water systems. [Link](#)
2. **Precision Electric (2025a)** – “Yaskawa Variable Frequency Drive – Overview, Comparisons & Services.” –In-depth guide comparing Yaskawa VFD features and industry benchmarks (reliability data, manufacturer comparisons, etc.). (Precision Electric, Inc. technical PDF)
3. **Precision Electric (2025b)** – “Switching from Allen-Bradley VFDs: Alternatives, Cost Savings & Services.” –Technical brief comparing VFD brands (ABB, Yaskawa, Eaton, Lenze, etc.) and highlighting their strengths relative to Rockwell AB. (Precision Electric, Inc. technical PDF)
4. **Yaskawa America** – Quality Summary – “Yaskawa Quality – Featured Product.” – Published reliability statistics: 100% testing, 0.0062% field failure rate, >28-year MTBF for Yaskawa drives. [Link](#)
5. **Precision Electric (2025c)** – “ABB VFD Drive Buying Guide: Choose the Right

- Model.” – Guide to ABB’s ACS series drives, including features like swinging chokes for IEEE 519 compliance, case study results (48% energy saving on pump, 30% HVAC capacity saving on regen crane). [Link](#)
6. **P.I. Process Instrumentation (2019)** – “Maximising energy savings through pump unit variable frequency drives.” – Article explaining affinity laws and impacts of VFD on pump energy, as well as motor considerations (harmonics, insulation) when using VFDs. [Link](#)
 7. **JP Motors & Drives (2013)** – “NEMA MG1 Guidelines for adjustable speed/motor applications.” – Technical overview of applying VFDs to motors, including NEMA MG1 Part 31 insulation requirements (1600V spikes), overload ratings, cooling concerns and other application notes. [Link](#)
 8. **AHRI / AHR Expo Presentation (2019)** – “Benefits of Utilising VFDs.” – An industry presentation including a case of multi-phase VFD retrofits (notably mentioning 16×250HP drives saving \$317k and 40×7.5-60HP drives saving \$152k annually, and overall 32% consumption reduction, 33% peak drop). (AHRI Expo 2019 conference paper)
 9. **Yaskawa GA500 Drive FAQs** – Yaskawa product Q&A database providing specifics on GA500 features: e.g. STO safety rating SIL3/PLe, maximum output frequency (590 Hz), 24 V backup supply, design life (10 years at 40°C 24/7). [Link](#) (See “What is the functional safety rating of the GA500?” etc.)
 10. **NEMA MG1 Standard (Part 30 and 31)** – (Referenced via NEMA and EASA guidelines) Defines the design requirements for motors on VFD power, including insulation spike resistance and vibration/ noise considerations.
 - [NEMA MG1 Part 31 summary](#) and [EASA Tech Manual].
 - [1 15 23 27 67 68 69 70](#) Energy Savings and Other Benefits of Variable Frequency Drives: City of Columbus Case Study – Ruekert & Mielke, Inc.
 - <http://www.ruekertmielke.com/blog/2021/variable-frequency-drives-benefits>
 - [2 13 16 17 31 32 45 46 47 56 57 63 64 84 85](#) Yaskawa Variable Frequency Drive (VFD) – Overview,

Comparisons & Services

- <https://www.precision-elec.com/wp-content/uploads/2025/07/Yaskawa-Variable->

[Frequency-Drive-VFD-%E2%80%93-Overview-Comparisons-Services.pdf?srsId=AfmBOoquLaKdPEhcg_ZC1SuBB-WYjW-rFNwQlbZxaDCqbpUOEgyLlkmB](#)

- [3 4 5 11 25](#) Maximising energy savings through pump unit variable frequency drives | P.I.

Process Instrumentation

- [https://www.piprocessinstrumentation.com/pumps-motors-drives/article/15564250/maximizing-energy-savings-through-pump-unit-variable-frequency-drives](#)
- [6 29 86](#)

GA500 Drive – Yaskawa

- [https://www.yaskawa.com/products/drives/industrial-ac-drives/microdrives/ga500-drive/-/content/_6221f998-7cdb-4843-bb58-c6309f9762a3_FAQs](#)
- [7](#) What is a Variable Frequency Drive? | iKnow Knowledge Base | Invertek Drives | Invertek Drives [https://www.invertekdrives.com/support/iknow/vfd-fundamentals/what-is-a-variable-frequency-drive](#)
- [8 12 14 18 24 28 30 35 36 37 38 83](#)
- ABB VFD Drive Buying Guide: Choose the Right Model [https://www.precision-elec.com/abb-vfd-drive-buying-guide/?srsId=AfmBOorVtV_cYQvpNcVJFMRrviZ7bKMq2cWt0-75zGiiU2E7KzS617jB|](#)
- [9 10 26](#) NEMA MG1 Guidelines for adjustable speed/motor applications – JP Motors & Drives [https://www.jpmotorsanddrives.com/nema-mg1-guidelines-for-adjustable-speedmotor-applications/](#)
- [19 20 21 22 79 80 81 82](#) Industrial Electronics Distributor & VFD Repair Experts
- [https://www.precision-elec.com/wp-content/uploads/2025/07/Precision-Electric-Industrial-Electronics-Distributor-VFD-Repair-Experts.pdf?srsId=AfmB0ooAOxeAsfEsLnluHxilmt71MnuENXycxuDKwv9i6CTmQDhcwdKz](#)
- [33 34](#) ACS580 – Effortless energy efficiency thanks to low and medium voltage VSDs | Highlights, References and materials | ABB [https://new.abb.com/drives/highlights-and-references/acs580-effortless-energy-efficiency?utm_source=chatgpt.com](#)

- [39 40](#) Yaskawa Quality from Yaskawa America, Inc. – Motion Division
<https://www.globalspec.com/FeaturedProducts/Detail/YaskawaAmericaMotionDivis>
- [41 42 43 44 48 49 50 51 52 53 54 55 58 59 60 61 62 65 66](#)

Switching from Allen-Bradley VFDs: Alternatives, Cost Savings & Precision Electric Services

- https://www.precision-elec.com/wp-content/uploads/2025/07/Switching-from-Allen-Bradley-VFDs_-Alternatives-Cost-Savings-Precision-Electric-Services.pdf?srltid=AfmBOopuBx3cakAWJyxjCA6f6PFIAZYxiakEcpNX66Dj3R9YQVgD3Nj8
- [71 72 73 74 75 76 77](#)

Benefits of Utilising VFDs

- https://www.ahrinet.org/system/files/2023-06/VFD_AHR_Expo_2019.pdf
- [78](#)

What is the energy-saving effect of a Variable Frequency Drive

- <https://www.wasinex.com/blog/what-is-the-energy-saving-effect-of-a-variable-frequency-drive-pump-181323.html>
- www.precision-elec.com

Frequently Asked Questions


How do VFDs help in saving energy?

VFDs control the motor speed based on actual needs, reducing energy consumption by avoiding constant running at full speed.

Can VFDs be used in all types of motors?

VFDs are suitable for most AC motors, but compatibility should be verified with the motor manufacturer.

Documents / Resources

	Precision Electric Variable Frequency Drives [pdf] Instruction Manual Variable Frequency Drives, Frequency Drives, Drives
---	--

References

- [User Manual](#)

📁 Precision
Electric

🔖 Drives, Frequency Drives, Precision Electric, Variable Frequency
Drives



Leave a comment

Your email address will not be published. Required fields are marked *

Comment *

Name

Email

Website

☐ Save my name, email, and website in this browser for the next time I comment.

Post Comment

Search:

e.g. whirlpool wrf535swhz

Search

[Manuals+](#) | [Upload](#) | [Deep Search](#) | [Privacy Policy](#) | [@manuals.plus](#) | [YouTube](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.