


RAB

T8-7-24G-8CCT-BYP
Double and Single Ended
Bypass Line Voltage



RAB T8-7-24G-8CCT-BYP Double and Single Ended Bypass Line Voltage Instructions


[Home](#) » [RAB](#) » RAB T8-7-24G-8CCT-BYP Double and Single Ended Bypass Line Voltage Instructions 

Contents

- [1 RAB T8-7-24G-8CCT-BYP Double and Single Ended Bypass Line Voltage](#)
- [2 SAFETY INFORMATION](#)
- [3 PRODUCTS NOTES](#)
- [4 INSTALLATION INSTRUCTIONS](#)
- [5 PRODUCT FEATURES](#)
- [6 Documents / Resources](#)
 - [6.1 References](#)

RAB

RAB T8-7-24G-8CCT-BYP Double and Single Ended Bypass Line Voltage



IMPORTANT

READ CAREFULLY BEFORE INSTALLING LED TUBE. RETAIN THESE INSTRUCTIONS FOR FUTURE REFERENCE.

RAB LED tube must be wired in accordance with the National Electrical Code and all applicable local codes. Proper grounding is required for Safety. THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.

WARNINGS

- Risk of fire or electric shock. LED Retrofit Kit installation requires knowledge of luminaires electrical systems. If not qualified, do not attempt installation. Contact a qualified electrician.
- Risk of fire or electric shock. Install this kit only in the luminaires that have the construction features and dimensions shown in the photographs and/or drawings and where the input rating of the retrofit kit does not exceed the input rating of the luminaire.
- To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects
- When the lamp is energized at the single end. To avoid potential fire or shock hazard, do not use this retrofit kit in luminaires employing shunted bi-pin lampholders.
- **Note:** Shunted lamp holders are found only in fluorescent luminaires with instant-start ballasts. Instant-start ballasts can be identified by the words "instant Start" or "I.S." marked on the ballast. This designation may be in the form of a statement pertaining to the ballast itself, or may be combined with the marking for the lamps with which the ballast is intended to be used, for example F40T12/IS. For more information, contact the LED luminaire retrofit kit manufacturer.

SAFETY INFORMATION

For your and others, please read the precautions carefully before installation:

1. Switch off the power supply before commencing work, make sure correct connection before power on.
2. NOT FOR EMERGENCY LIGHTING.
3. Only use the control provided with or specified by these instructions to control this lamp. This lamp will not operate properly when connected to a standard (incandescent) dimmer or dimming control. This lamp can dimmed by specified dimmer, please consult with manufacture for detailed dimmer information.
4. Switch off the power supply before turning the wattage switch and CCT switch on the tube.

WARNING

- Installers should not disconnect existing wires from lampholder terminals to make new connections at lampholder terminals. Instead installers should cut existing lampholder leads away from the lampholder and make new electrical connections to lampholder lead wires by employing applicable connectors.
- Do not make or alter any open holes in an enclosure of wiring or electrical components during kit installation. THE RETROFIT ASSEMBLY IS ACCEPTED AS A COMPONENT OF A LUMINAIRE WHERE THE SUITABILITY OF THE COMBINATION SHALL BE DETERMINED BY UL OR AUTHORITIES HAVING JURISDICTION.
- THERE ARE LED TUBE, OPERATION INSTRUCTION AND FIELD APPLIED LABEL IN THIS RETROFIT KIT.
- Type B LAMP-intended for operation in luminaires with traditional fluorescent-type lamp holders wired directly to

the branch circuit. This includes both factory-wired luminaires as well as those converted for this purpose under a retrofit program.

PRODUCTS NOTES

The units covered by this report were intended to retrofit surface mount, Type IC or non-IC recessed mount Listed fluorescent luminaires that use maximum 4 tubular lamps, the minimum lamp compartment dimensions are tabulated below:

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.


Model Name	Minimum Lamp Compartment Dimensions Length x Width x Height (in)	Maimum Lamp Q uantity	Lamp to lamp Spacing (in)
(T10292)T8-7-24G-8CCT-BYP	24 x 24 x 1.97	4	4.33
(T10293)T8-9-36G-8CCT-BYP	36 x 24 x 1.97	4	4.33
(T10294)T8FA-9.5-48G-8CCT-BYP	48 x 24 x 1.97	4	4.33
(T10295)T8FA-10.5-48G-8CCT-BYP	48 x 24 x 1.97	4	4.33

INSTALLATION INSTRUCTIONS


The socket should be non-shunted
The below ballast wiring represents typical configuration. The actual ballast wiring varies according to ballast model.

Single Ended Wiring Instruction


Retrofit luminaire with 1 lamp




Retrofit luminaire with 2 lamps



Retrofit luminaire with 3 lamps



Retrofit luminaire with 4 lamps




The below ballast wiring represents typical configuration. The actual ballast wiring varies according to ballast model. It is not needed to change socket (if in good condition) to operate double ended lamps, regardless the type of sockets. Please make sure one side of fixture is connected to Live (L) and the other side to Neutral (N).


Double Ended Wiring Instruction

Retrofit luminaire with 1 lamp

Instant Start




Program Start or Rapid Start




Retrofit luminaire with 2 lamps

Instant Start




Program Start or Rapid Start




Retrofit luminaire with 3 lamps

Instant Start





Program Start or Rapid Start





Retrofit luminaire with 4 lamps

Instant Start





Program Start or Rapid Start




PRODUCT FEATURES

Single ended & Double ended



CCT & Power selectable



CCT selectable

(T10292)T8-7-24G-8CCT-BYP
(T10293)T8-9-36G-8CCT-BYP



CCT selectable
Power selectable

(T10294)T8FA-9.5-48G-8CCT-BYP
(T10295)T8FA-10.5-48G-8CCT-BYP


Note: These instructions do not cover all details or variations in equipment nor do they provide for every possible situation during installation, operation or maintenance.

Visit our website for product info rablighting.com

e-mail Answered promptly- sales@rablighting.com

RAB WARRANTY: RAB', warranty is subject to o/1 terms and conditions found at rablighting.com/warranty

Documents / Resources



[RAB T8-7-24G-8CCT-BYP Double and Single Ended Bypass Line Voltage \[pdf\]](#) Instructions
T8-7-24G-8CCT-BYP, T8-9-36G-8CCT-BYP, T8FA-9.5-48G-8CCT-BYP, T8FA-10.5-48G-8CCT-BYP, T8-7-24G-8CCT-BYP Double and Single Ended Bypass Line Voltage, T8-7-24G-8CCT-BYP, Double and Single Ended Bypass Line Voltage, Single Ended Bypass Line Voltage, Ended Bypass Line Voltage, Bypass Line Voltage, Line Voltage, Voltage

References

- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.