

SATEC EDL180 Portable Event and Data Logger



SATEC EDL180 Portable Event and Data Logger Instruction Manual

[Home](#) » [SATEC](#) » SATEC EDL180 Portable Event and Data Logger Instruction Manual 

Contents

- 1 SATEC EDL180 Portable Event and Data Logger
- 2 LIMITED WARRANTY
- 3 Physically supplied content
- 4 Front Panel Components
- 5 Installation/wiring
- 6 Specification
- 7 Documents / Resources
 - 7.1 References



SATEC EDL180 Portable Event and Data Logger



EDL180

Portable Event & Data Logger Installation & Operation Manual

BG0647 REV.A1

LIMITED WARRANTY

- The manufacturer offers the customer functional warranty for 36 months from the date of production. This warranty is on a return to factory basis.
- The manufacturer does not accept liability for any damage caused by instrument malfunction. The manufacturer accepts no responsibility for the suitability of the instrument to the application for which it was purchased.
- Failure to install, set up or operate the instrument according to the instructions herein will void the warranty.
- Only a duly authorized representative of the manufacturer may open your instrument. The unit should only be opened in a fully anti-static environment. Failure to do so may damage the electronic components and will void the warranty.
- The greatest care has been taken to manufacture and calibrate your instrument. However, these instructions do not cover all possible contingencies that may arise during installation, operation or maintenance, and all details and variations of this equipment are not covered by these instructions.
- For additional information regarding installation, operation or maintenance of this instrument, contact the manufacturer or your local representative or distributor.
- For more details concerning technical assistance & support visit manufacturer's web site:
 - www.satec-global.com

NOTE:

The greatest care has been taken to manufacture and calibrate your instrument. However, these instructions do not cover all possible contingencies that may arise during installation, operation or maintenance, and not all details and variations of this equipment are covered by these instructions. For additional information regarding installation, operation or maintenance of this instrument, contact the manufacturer or your local representative or distributor.

SUPPLEMENTARY INSTRUCTIONS:

This manual provides instructions for using the EDL180. For instructions and information on using the PM180, refer to the PM180 Installation and Operation Manual; for instructions and information on using the PAS software package, refer to the PAS User's Manual included in the accompanying CD for the PM180 Series.

Portable Event & Data Logger

1. The EDL180 Portable Event & Data Logger measures, records and analyzes events and data of electrical network parameters. Being mobile, it enhances efficiency by enabling onsite identification of power problems. The EDL180 meets the requirements of a wide range of applications, from event analysis to energy auditing and load profile recording over a set time period.
 - The EDL180 parameters include all the measurement and logging capabilities of the PM180 power quality analyzer in a convenient, portable case. The manufacturer's PAS software suite, available online, is provides graphic data display and power quality analysis capabilities.
 - The EDL180 is suitable for direct measurement of voltages up to 828V AC (or greater when using a

Potential Transformer). The EDL180 is provided with standard current clamps featuring a range of options between 30-3,000A AC nominal current with nominal 2V AC or 3V AC outputs. The starting measured current of the flex cables provided by SATEC is 10A AC.

- Internal UPS for independent power supply The EDL180 has an internal UPS providing over 4 hours of power supply during loss of external power, such as during a general power failure.

NOTE:

- Device configuration and complementary technical specifications are identical to those of the PM180. See the PM180 Installation and Operation Manuals for full connection drawings and instructions.

Physically supplied content

1. EDL180 analyzer
2. carry bag
3. Power cable (EU plug)
4. **voltage probe set:** 4 colored cables (yellow, blue, red and black) with crocodile connectors
5. **Flex current sensors:** 4 units according to ordered model:
 - **30/300/3,000A model:** requires battery (not supplied)
 - **200A model:** does not require battery
6. **USB cable:** type A to type A

Read through this section carefully before connecting the EDL180 to the circuit being tested.

Front Panel Components




Figure 1: Front panel components, inputs and outputs

1	AC Power Supply Socket
2	Fuse
3	Power-on switch
4	RGM display module
5	ETH port
6	Current-clamp inputs
7	Voltage inputs
8	USB-A port
9	screen
10	Energy pulse LED
11	IR port
12	USB-A port
13	LED battery level indicators
13	battery charging status LED

Installation/wiring

Read through this section carefully before connecting the EDL180 to the circuits being tested/analyzed.

1. Location

The distance between the EDL180 and the current lines must be at least half a meter (1.6 feet) for current lines carrying up to 600A, and at least one meter (3.3 feet) for currents between 600A and 3,000A.

2. Power Supply and UPS Charging

Connect the EDL180 to AC power supply using the Power Supply Cord provided. Turn the power switch (No. 3) ON.

Once the unit is connected to an external power supply, the UPS battery automatically starts charging, regardless of whether the unit is powered on or not.

3. LED Charging Indicators

The unit features 4 LEDs: 3 indicating battery level (13) and one indicating charging status (14): red = charging; blue = full.

4. Voltage Probes Connection

For voltage readings use the supplied voltage probes. connect the voltage probes' outputs to the EDL180 through the voltage 4mm sockets marked V1/V2/V3/VN. Connect the probes to the power line conductors according to the power system configuration / siring mode (See figure 2 below). For alternative line configurations please consult the PM180 installation manual.

WARNING: the voltage between phases (V1, V2, V3) must not exceed 828V.

5. Current Sensors Connection

Connect the current sensors' outputs first to the EDL180 and then to the measured circuits, by either wrapping the probe around the line or via clamp, in accordance with ordered/supplied model.

6. Standard FLEX Current Sensors

The EDL180 can work with all FLEX and clamp current sensors featuring a voltage output up to 6V AC.

However, for locally sourced sensors, make sure to contact the manufacturer for confirmation of compliance and instructions.

7. Configuring Wiring Mode and CT Ratings

The wiring mode of the EDL180 is the same as for the PM180. See standard example below (figure 2). For alternative line configurations please refer to the PM180 Installation and PM180 Operation manuals (separate documents).




Figure 2 Four wire WYE Direct connection, using 3 CTs (3-element) wiring mode

Configuring CT values: For the coil ranging 30-3,000A AC, featuring CT ratio output of 1kA/1V AC, nominal current is determined on coil integrator by scale switch (image 3 below) and must be set in unit according to selection.

For the permanently rated 200A clamp, featuring CT ratio of 1.5kA/1V AC nominal current, nominal current must be adjusted and set at 300A and NOT at the presumed 200A.



Figure 3 Rated-current Switch





- Nominal current is set in the device either via RGM screen or via PAS as described in the manuals mentioned below.
- Configuration using the RGM180 front Panel
- For configuration of the wiring mode and CT values via the RGM180 front panel, refer to the Wiring Setup instructions in the RGM180 QuickStart Manual.
- Configuration using PAS software
- For configuration via Power Analysis Software (PAS) please refer to the above PM180 manuals.

Internal Uninterrupted Power Supply

- The EDL180 includes a rechargeable UPS. When fully charged, the UPS allows the EDL180 to work for over 4 hours at maximum consumption. It is recommended to switch off the unit when not in use to prevent discharge. However, discharge has not been reported to harm the UPS battery.



Specification

- Power supply: 90-264V AC @ 50-60Hz
- UPS Battery Pack: rechargeable; 3.7V * 15,000mAh DC. Tested for over 4 hours of power of full consumption/burden (unit + RGM screen).
- **UPS characteristics:**
 - Battery output voltage $3.7V * 3 = 11.1V$
 - Over charge protection
 - Over discharge protection
 - Over current protection
 - Over discharge protection
 - Short protection
- **Accuracy:** The EDL180 accuracy is set by the combined accuracies of the PM180, current clamps and the PT, if used. The common factors are the unit accuracy and that of the current clamps, which are the dominant factor.
- **Operation temperature:** 0-60°C
- **Humidity:** 0 to 95% non-condensing
- **Dimensions (facing front panel):**
 - Height 190 mm, (7.5"), Width 324 mm, (12.7") Depth (incl. RGM screen) 325 mm, (12.8")
- **Unit Weight:** 4.6 KG (10.2 lbs); Unit with carry bag, voltage probes and power cord: 6.9 KG (15.2 lbs)



BG0647 REV.A1

Documents / Resources

 <p>EDL180 Portable Event & Data Logger Installation & Operation Manual</p> 	<p>SATEC EDL180 Portable Event and Data Logger [pdf] Instruction Manual</p> <p>EDL180, EDL180 Portable Event and Data Logger, Portable Event and Data Logger, Data Logger, Logger</p>
--	---

References

- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.