

SENECA ZE-2AI Automation Interfaces Ethernet Instruction Manual

Home » SENECA » SENECA ZE-2AI Automation Interfaces Ethernet Instruction Manual



Contents

- 1 SENECA ZE-2Al Automation Interfaces
- **Ethernet**
- **2 PRELIMINARY WARNINGS**
- **3 CONTACT INFORMATION**
- **4 MODULE LAYOUT**
- **5 TECHNICAL SPECIFICATIONS**
- **6 INSTALLATION REGULATIONS**
- **7 FACTORY IP ADDRESS**
- **8 Modbus Connection Rules**
- 9 SETTING THE DIP-SWITCHES
- **10 ELECTRICAL CONNECTIONS**
- 11 Documents / Resources
- 11.1 References
- **12 Related Posts**



SENECA ZE-2AI Automation Interfaces Ethernet



PRELIMINARY WARNINGS

The word WARNING preceded by the symbol indicates conditions or actions that put the user's safety at risk. The word ATTENTION preceded by the symbol indicates conditions or actions that might damage the instrument or the connected equipment. The warranty shall become null and void in the event of improper use or tampering with the module or devices supplied by the manufacturer as necessary for its correct operation, and if the instructions contained in this manual are not followed.

- **WARNING**: The full content of this manual must be read before any operation. The module must only be used by qualified electricians. Specific documentation is available via QR-CODE shown on page 1.
- The module must be repaired and damaged parts replaced by the Manufacturer. The product is sensitive to electrostatic discharges. Take appropriate measures during any operation.
- Electrical and electronic waste disposal (applicable in the European Union and other countries with recycling).
 The symbol on the product or its packaging shows the product must be surrendered to a collection centre authorized to recycle electrical and electronic waste.








- DOCUMENTATION ZE-4DI-2AI-2DO
- DOCUMENTATION Z-4DI-2AI-2DO
- DOCUMENTATION ZE-2AI
- SENECA s.r.l.; Via Austria,
- 26 35127 PADOVA
- ITALY; Tel. +39.049.8705359
- Fax +39.049.8706287


CONTACT INFORMATION

- · Technical support
- support@seneca.it
- Product information
- · sales@seneca.it

This document is the property of SENECA srl. Copies and reproduction are prohibited unless authorized. The content of this document corresponds to the described products and technologies. Stated data may be modified or supplemented for technical and/or sales purposes.

MODULE LAYOUT





• Single module dimensions LxHxD: 17.5 x 102.5 x 111 mm;

• Weight: 110 g;

• Enclosure: PA6, black

• Double module dimensions LxHxD: 35 x 102.5 x 111 mm;

• Weight: 110 g;


• Enclosure: PA6, black

LED SIGNALS ON THE FRONT PANEL (ZE-4DI-2AI-2DO)

LED SIGNALS ON THE FRONT PANEL (Z-4DI-2AI-2DO)

LED SIGNALS ON THE FRONT PANEL (ZE-2AI)

TECHNICAL SPECIFICATIONS



POWER SUPPLY	Voltage: 11 ÷ 40Vdc; 19 ÷ 28Vac 50 ÷ 60Hz Absorption: Typical: 1,5 W @ 24Vdc, Max: 4 W (ZE-4DI-2AI-2DO Z-4DI-2AI-2DO) Absorption: Typical: 1,5 W @ 24Vdc, Max: 2 W (ZE-2AI)	
DIGITAL INPUTS only ZE-4DI-2AI-2DO Z-4DI-2AI-2DO	Number of channels 4. Configurable PNP or NPN. Voltage input OFF < 4V, ON > 8V (max. 24 Vdc). Current input 20 mA. Max frequency 5 KHz. Absorbed current 3mA@12Vdc, 10mA@24Vdc.	
COUNTERS only ZE-4DI-2AI-2DO Z-4DI-2AI-2DO	4 32bit resettable counters on non-volatile memory.	
DIGITAL OUTPUTS only ZE-4DI-2AI-2DO Z-4DI-2AI-2DO	Number of channels 2. SPDT free contact relay. Max. voltage 250Vac. Max. current 2 A.	
ANALOGUE INPUTS		
COMMUNICATION PORTS	Ethernet 100 base R.145 front (/F-41)1-241-2100 /F-241)	

INSTALLATION REGULATIONS

The module has been designed for vertical installation on a DIN 46277 rail. For optimal operation and long life, adequate ventilation must be provided. Avoid positioning ducting or other objects that obstruct the ventilation slots. Avoid mounting modules over heat-generating equipment. Installation in the bottom part of the electrical panel is recommended.

CAUTION

These are open type devices intended for installation in a final casing/panel that offers mechanical protection and protection against the spread of fire.

FACTORY IP ADDRESS

The default module IP address is static: 192.168.90.101

WEB SERVER


To access the maintenance Web Server with 192.168.90.101 factory IP address: Default user: admin, Default password: admin, http://192.168.90.101


Modbus Connection Rules

- 1. Install the modules in the DIN rail (120 max)
- 2. Connect the remote modules using cables of an appropriate length. The following table shows cable length data:
 - Bus length: maximum length of the Modbus network according to the Baud Rate. This is the length of

the cables that connect the two farthest modules (see Diagram 1).

• Derivation length: maximum length of a derivation 2 m (see Diagram 1).






For maximum performance, it is recommended to use special shielded cables, designed specifically for data communication.

USB PORT (Z-4DI-2AI-2DO)


The module is designed to exchange data according to the modes defined by the MODBUS protocol. It has a micro USB connector on the front panel and can be configured using applications and/or software programs. The USB serial port uses the following communication parameters: 115200,8,N,1. The USB communication port responds exactly like the serial ports, with the exception of the communication parameters. For more information, visit the site shown on page 1.



Check that the device in question is included in the list of products supported by the Easy Setup APP in the store.

CONNECTOR IDC10

Power supply and Modbus interface are available using the Seneca DIN rail bus, via the IDC10 rear connector, or the Z-PC-DINAL-17.5 accessory.



Back connector (IDC 10)

The illustration shows the meanings of the various IDC10 connector pins if signals are to be sent via them directly.

SETTING THE DIP-SWITCHES

WARNING

The DIP-switch settings are read-only at boot time. At each change, perform a restart. SW1 DIP-SWITCH: Through DIP-SWITCH-SW1 it is possible to set the IP configuration of the device:

KEY						
1	ON					
0	OFF					

DESCRIPTION	DIP 1	DIP 2
To obtain the configuration from the Flash memory, both SW1 DIP switch selectors must be set to OFF		
To reset the device to factory settings both SW1 DIP switches must be set to ON		
To force the device's IP address to the standard value of SENECA Ethernet products: 192.168.90.101		
Reserved		

RS232/RS485 SETTING: RS232 or RS485 configuration on terminals 10-11-12 (serial port 2)


SW2					
1	ON		RS232 ACTIVATION		
0	OFF		RS485 ACTIVATION		

ELECTRICAL CONNECTIONS

Attention: the upper power supply limits must not be exceeded, as this might cause serious damage to the module. To meet the electromagnetic immunity requirements:

- use shielded signal cables;
- connect the shield to a preferential instrumentation earth system;
- separate shielded cables from other cables used for power installations (transformers, inverters, motors, induction ovens, etc.).

POWER SUPPLY




The power supply is connected to terminals 2 and 3.

The supply voltage must be between:

11 and 40Vdc (indifferent polarity), or between 19 and 28 Vac.

The power supply source must be protected from any failures in the module by means of a suitably sized fuse.

ANALOGUE INPUTS



Documents / Resources



SENECA ZE-2AI Automation Interfaces Ethernet [pdf] Instruction Manual ZE-4DI-2AI-2DO, Z-4DI-2AI-2DO, ZE-2AI, Automation Interfaces Ethernet, ZE-2AI Automation Interfaces Ethernet, Interfaces Ethernet, Ethernet

References

- S seneca.it/products/z-4di-2ai-2do/doc/CE_declaration
- S seneca.it/products/ze-2ai/doc/CE declaration
- Sseneca.it/products/ze-4di-2ai-2do/doc/CE declaration

Manuals+,