

THERMON Terminator ZT-C-P-XP Thermostat Connection Kit Instruction Manual

Home » THERMON Terminator ZT-C-P-XP Thermostat Connection Kit Instruction Manual

THERMON Terminator ZT-C-P-XP Thermostat Connection Kit



Contents

- 1 INSTALLATION PROCEDURES
 - 1.1 Kit Contents
 - 1.2 Order Separately
 - 1.3 Tools Required
 - 1.4 Receiving, Storing and Handling
 - 1.5 Dimensions
 - 1.6 Warnings
 - 1.7 Specific Conditions of Use
 - 1.8 Certifications/Approvals
 - 1.9 Wiring Details
 - 1.10 Two-Cable Layout Tips
- **2 Customer Support**
- 3 Documents / Resources
 - 3.1 References
- **4 Related Posts**

INSTALLATION PROCEDURES

The following installation procedures are suggested guidelines for the installation of the Terminator ZT-P-XP and ZT-C-P-XP Kits

Kit Contents




Item	Quantity	Description
1	1	Expediter Assembly Support Cap with O-Ring Threaded Grommet Compressor Grommet Support Base with O-Ring
2	1	Junction Box Lid
3	1	Junction Box Base w/O-Ring and M25 Dust Cap
4	1	Nut
5	1	Banding
6	1	Banding Guide
7	1	Thermostat w/ Terminal Blocks (Refer to terminal specifications for maximum allowable wire size) Thermostat Type ZT-C-230 Vac 4 mm2 terminals T-C-400 Vac 6 mm2 terminals
	1	Junction Box Cord
9	2	Blind Plug

Order Separately

PETK Power and End Termination Kits (per cable)


- PETK-1 for RSX, VSX, VSX-HT, BSX
- PETK-2 for KSX, HTSX, USX
- **PETK-3-**ZT for HPT, FP



Item	Quantity	Description
1	1	RTV Tube
2	1	Power Connection Boot
3	1	Ground Sleeve
4	1	End Cap
5	1	Tape Strip (PETK-3-ZT only)
6	1	Grommet (PETK-3-ZT only)
7	1	End Termination Caution Label

Tools Required

• 3 mm 8 mm



• Terminator-LN-Tool (order separately)




• 28 mm



Receiving, Storing and Handling

- 1. Inspect materials for damage incurred during shipping.
- 2. Report damages to the carrier for settlement.
- 3. Identify parts against the packing list to ensure the proper type and quantity has been received.
- 4. Store in a dry location.

Dimensions



Warnings

- Due to the risk of electrical shock, arcing and fire caused by product damage or improper usage, installation or maintenance, a ground-fault protection device is required.
- Installation must comply with Thermion requirements (including form PN 50207U for Ex systems) and be
 installed in accordance with the regulations as per the norm EN IEC 60079-14 for hazardous areas (where
 applicable), or any other applicable national and local codes.
- Component approvals and performance ratings are based on the use of Thermon specified parts only.
- De-energize all power sources before opening enclosure.
- Avoid electrostatic charge. Clean only with a damp cloth.

- Keep ends of heating cable and kit components dry before and during installation.
- Minimum bending radius of heating cable is 32 mm (except HPT is 57 mm and FP is 19 mm).
- Individuals installing these products are responsible for complying with all applicable safety and health guidelines. Proper Personal Protective Equipment (PPE) should be utilized during installation. Contact Thermon if you have any additional questions.
- Consult the manufacturer for dimensional information on the flameproof joints for repair.

Specific Conditions of Use

- 1. Consult the manufacturer for dimensional information on the flameproof joints for repair.
- 2. Avoid electrostatic charge. Clean only with a damp cloth.
- 3. T5 and T100°C for switching amperage of thermostat limited to 25 Amps maximum.
- 4. T6 and T85°C for switching amperage of thermostat limited to 16 Amps maximum.

Certifications/Approvals

IP66; -60°C \leq Ta \leq +55°C T6, 85°C 16 Amps Max -60°C \leq Ta \leq +50°C T5, 100°C 25 Amps Max Ordinary & **Hazardous Locations**

Terminator ZT



FMG 10.0022X Ex db eb IIC T6...T5 Gb Ex tb IIIC T85°C...T100°C Db



II 2 GD Ex db eb IIC T6...T5 Gb, Ex tb IIIC T85°C...T100°C Db FM10ATEX0058X

Terminator ZT-C




EPS 19.0094X Ex db eb IIC T5-T6, Ex tb IIIC T100°C-T85°




19ATEX1216X


1. Locate bus connection (HPT and FP only) and cable as shown. Cut end of cable at angle to aid in piercing grommet. Leave additional cable for expansion loop. See page 5 for multiple cable installation tips




2. For HPT and FP cable, exchange grommet in Terminator with grommet provided in PETK-3-ZT




3. Insert cable into expediter. If mounted on bottom or side of pipe, punch out weep hole.




4. Slide expediter toward pipe and route cable through support base entr




5. Insert banding guide into expediter and snap into place




6. Mount expediter to pipe using pipe band. Do not band over cable.




7. Cut off end of cable.




8. Terminate cable with appropriate PETK termination kit. Refer to PETK installation instructions. Push excess cable back through expediter. Tighten cap securely. Tape cable expansion loop to pipe.




9. Remove expediter from pipe by removing pipe band.




10. Route thermostat bulb through nut and expeditor opening in junction box base. If necessary, apply lubricant (user supplied) to end of thermostat bulb. Slide through conical grommet hole. Push excess capillary tube through expeditor



11. Fix thermostat bulb and capillary tube to pipe.




12. Mount expediter to pipe using pipe band. Do not band over cable. Tape cable expansion loop to pipe.




13. Take out thermostat. Mount junction box base on expediter. Make sure to align slots to properly orient junction box base.


Tighten nut with Terminator-LN-Tool. If mounting horizontally, threaded gland holes must face downward.




14. Remove M25 dust cap. Install M25 power gland (order separately) and M25 blind plugs.



15. Install power cable (if necessary)




16. Install thermostat and complete system wiring. Terminal set screws shall be tightened to a torque value of 1.4 Nm (12.4 lb-in). See page 5 for wiring details. Set thermostat at desired setpoint.




17. Install junction box lid and twist hand tight. Insert screwdriver into ratchet slots located on side of junction box

base. Use screwdriver to ratchet on junction box lid. Lid will rotate 30 degrees.




18. Lid latch mechanism fully engaged.

To remove lid, repeat step 17 but in the opposite direction.




Wiring Details

Thermostat Connection (1 or 2 Heating Cables)




Thermostat Connection (1 Heating Cable Shown) 400 Vac Option.




Two-Cable Layout Tips

Locate bus connection (HPT and FP only) and cable as shown. Cut end of cable at angle to aid in piercing grommet. Leave additional cable for expansion loop.



Insert two cables into expediter.

Note: For HPT and FP cable, exchange grommet in Terminator with grommet provided in PETK-3-ZT.



Customer Support

European Headquarters: Boezemweg 25 • PO Box 205 • 2640 AE Pijnacker • The Netherlands • Phone: +31 (0) 15-36 15 370

Corporate Headquarters: 100 Thermon Dr • PO Box 609 San Marcos, TX 78667-0609 • Phone: 512-396-5801 • 1-800-820-4328

For the Thermon office nearest you visit us at . . . www.thermon.com



Documents / Resources



THERMON Terminator ZT-C-P-XP Thermostat Connection Kit [pdf] Instruction Manual Terminator ZT-C-P-XP Thermostat Connection Kit, Terminator ZT-C-P-XP, Thermostat Connection Kit, Connection Kit



References

Search World Leader in Industrial Process Heating | Thermon

Manuals+,