



TRANE ACC-SVN85C-EN Enthalpy Sensor Control Instruction Manual

[Home](#) » [Trane](#) » TRANE ACC-SVN85C-EN Enthalpy Sensor Control Instruction Manual 



Installation Instructions Enthalpy Sensor Control



Model Number:
BAYENTH001

Used With:
BAYECON054, 055, and 073
BAYECON086A, 088A

SAFETY WARNING

Only qualified personnel should install and service the equipment. The installation, starting up, and servicing of heating, ventilating, and air-conditioning equipment can be hazardous and requires specific knowledge and training.

Improperly installed, adjusted or altered equipment by an unqualified person could result in death or serious injury. When working on the equipment, observe all precautions in the literature and on the tags, stickers, and labels that are attached to the equipment.

November 2024 ACC-SVN85C-EN

Contents

- 1 Warnings and Cautions
- 2 Installation
- 3 Operation
- 4 Troubleshooting
- 5 Wiring
- 6 Documents / Resources
 - 6.1 References

Warnings and Cautions

Overview of Manual

Note: One copy of this document ships inside the control panel of each unit and is customer property. It must be retained by the unit's maintenance personnel.

This booklet describes proper installation, operation, and maintenance procedures for air cooled systems. By carefully reviewing the information within this manual and following the instructions, the risk of improper operation and/or component damage will be minimized.

It is important that periodic maintenance be performed to help assure trouble free operation. A maintenance schedule is provided at the end of this manual. Should equipment failure occur, contact a qualified service organization with qualified, experienced HVAC technicians to properly diagnose and repair this equipment.

Hazard Identification

Warnings and Cautions appear at appropriate sections throughout this manual. Read these carefully.



WARNING

Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.



CAUTION

Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury. It may also be used to alert against unsafe practices.



CAUTION

Indicates a situation that may result in equipment or property-damageonly accidents.

Model Number Description

All products are identified by a multiple-character model number that precisely identifies a particular type of unit. Its use will enable the owner/operator, installing contractors, and service engineers to define the operation, specific components, and other options for any specific unit.

When ordering replacement parts or requesting service, be sure to refer to the specific model number and serial number printed on the unit nameplate.

General Information

The solid state enthalpy sensor is used with a solid state economizer actuator motor.

Installation

Installation For BAYECON054,055 Downflow Discharge Economizer Single Enthalpy Sensor (Outdoor Air Only)




Figure 1.

1. Units with economizers already installed: When installing the enthalpy sensor after the economizer has been installed remove the economizer/filter access panel located on the return side of the unit.
2. Remove the two screws securing the disk type thermostat to the top of the motor deck.
3. Next, disconnect the wires 56A and 50A(YL) from the thermostat.
4. Using the two screws removed in step 2, mount the Enthalpy sensor in the thermostat's previous location, Figure 1.
5. Connect wire 56A to S and 50A(YL) to + terminals on the Enthalpy Sensor.
6. On the Control Module (Solid State Economizer Logic Module) attached to the Economizer Motor, remove the red resistor from terminals SR and + and discard. See Figure 3.
7. Remove the white resistor from between the SO terminal and wire 56A. Then install the white resistor across the SR and + terminals
8. Install the terminal adaptor provided with the sensor on terminal SO of the Control Module and connect wire 56A to it.
9. Replace the economizer/filter access panel.

Installation for Differential Enthalpy Sensing (Outside Air & Return Air)




Figure 2.

1. Complete the procedures for installing a single enthalpy sensor.
2. Mount the second enthalpy sensor on the bottom side of the motor deck, see Figure 2.
3. Remove the knockout located below the Economizer Motor and insert a snap bushing.
4. Install field supplied wires through the snap bushing from terminals S and + on the return enthalpy sensor to the SR and + terminals on the Control Module.
5. On the Control Module attached to the Economizer Motor, remove the white resistor from between the SR terminal and the + terminal. Then connect the wire from S on the sensor to SR on the Control Module and + on the sensor to + on the Control Module.




Figure 3. Control module before installation




Figure 4. Control module with one enthalpy sensor




Figure 5. Control module with two enthalpy sensors

Installation for BAYECON073 Horizontal Discharge Economizer: Single Enthalpy Sensor (Outdoor Air Only)

1. Units with economizers already installed: When installing the enthalpy sensor after the economizer has been installed remove the economizer rain hood.
2. Remove the two screws securing the disk type thermostat on the damper side of the economizer.
3. Next, disconnect the wires 56A and 50A(YL) from the thermostat.
4. Using the two screws removed in step 2, mount the Enthalpy sensor on the outside face of the economizer. See Figure 6.
5. Connect wire 56A to S and 50A(YL) to + terminal on the Enthalpy sensor.
6. Remove the filter access panel on the return side of the unit reach into the Control Module attached to the Economizer Motor, remove the red resistor from terminals SR and + and discard. See Figure 3.
7. Remove the white resistor from between the SO terminal and wire 56A. Than install the white resistor across the SR and + terminals

8. Install the terminal adaptor provided with the sensor on terminal SO of the Control Module and connect wire 56A to it.
9. Reinstall the rain hood and filter access panel.

Installation for Differential Enthalpy Sensing

1. Complete the procedures for installing a single enthalpy sensor.
2. Mount the second enthalpy sensor in the return air stream See Figure 6.




Figure 6.

3. Install field supplied wires through from terminals S and + on the return enthalpy sensor to the SR and + terminals on the Control Module.
4. On the Control Module (Solid State Economizer Logic Module) attached to the Economizer Motor, remove the white resistor from between the SR terminal and the + terminal. Then connect the wire from S on the sensor to SR on the Control Module and + on the sensor to + on the Control Module.


Installation for BAYECON086A, BAYECON088A Downflow Discharge

Single Enthalpy Sensor (Outdoor Air Only)

1. Units with economizers already installed: When installing the enthalpy sensor after the economizer has been installed remove the economizer/filter access panel located on the front side of the unit. Remove the mist eliminator and retaining angle from the economizer.
2. Remove the two screws securing the disk type thermostat to the rear panel.
3. Disconnect the wires 182A(YL) and 183A(YL) from the thermostat.
4. Locate bushing supplied with kit and pull wires 182A(YL) and 183A(YL) through bushing. Snap bushing into the hole where the thermostat was removed.
5. Connect wire 182A(YL) to S and 183A(YL) to + terminals on the Enthalpy Sensor.
6. Using the two screws removed in step 2, mount the Enthalpy sensor adjacent to thermostat's previous location, Engagement holes are provided.
7. On the Control Module (Solid State Economizer Logic Module) attached to the Economizer Motor, remove the red resistor from terminals SR and + and discard. See Figure 3.
8. Remove the white resistor from between the SO terminal and wire 182A(YL). Then install the white resistor

across the SR and + terminals

9. Install the terminal adaptor provided with the sensor on terminal SO of the Control Module and connect wire 182A(YL) to it.
10. Replace the economizer/filter access panel and mist eliminator.



1. Complete the procedures for installing a single enthalpy sensor.
2. Mount the second enthalpy sensor on the bottom side of the Return Air Blockoff.
3. Remove the knock-out located near the front side of the Return Air Blockoff and insert a snap bushing.
4. Install field supplied wires through the snap bushing from terminals S and + on the return enthalpy sensor to the SR and + terminals on the Control Module.
5. On the Control Module attached to the Economizer Motor, remove the white resistor from between the SR terminal and the + terminal and discard. Then connect the wire from S on the sensor to SR on the Control Module and + on the sensor to + on the Control Module.

Installation for BAYECON086A, BAYECON088A

Horizontal Discharge

Single Enthalpy Sensor (Outdoor Air Only)

1. Units with economizers already installed: When installing the enthalpy sensor after the economizer has been installed remove the economizer/filter access panel located on the front side of the unit. Remove the mist eliminator and retaining angle from the economizer.
2. Remove the two screws securing the disk type thermostat to the rear panel.
3. Disconnect the wires 182A(YL) and 183A(YL) from the thermostat.
4. Locate bushing supplied with kit and pull wires 182A and 183A) through bushing. Snap bushing into the hole where the thermostat was removed.
5. Connect wire 182A to S and 183A to + terminals on the Enthalpy Sensor.
6. Using the two screws removed in step 2, mount the Enthalpy sensor adjacent to thermostat's previous location, Engagement holes are provided.
7. On the Control Module (Solid State Economizer Logic Module) attached to the Economizer Motor, remove the red resistor from terminals SR and + and discard.
8. Remove the white resistor from between the SO terminal and wire 182A. Then install the white resistor across the SR and + terminals
9. Install the terminal adaptor provided with the sensor on terminal SO of the Control Module and connect wire

182a to it.

10. Replace the economizer/filter access panel and mist eliminator.

Installation for Differential Enthalpy Sensing (Two Sensors)

1. Complete the procedures for installing a single enthalpy sensor.
2. Mount the second enthalpy sensor on the side of the return air hood
3. Remove the knock-out located near the front side of the Return Air Bolckoff and insert a snap bushing.
4. Install field supplied wires through the snap bushing from terminals S and + on the return enthalpy sensor to the SR and + terminals on the Control Module.
5. On the Control Module attached to the Economizer Motor, remove the white resistor from between the SR terminal and the + terminal and discard. Then connect the wire from S on the sensor to SR on the Control Module and + on the sensor to + on the Control Module.

Installation for BAYECON101, BAYECON102, BAYECON105, BAYECON106 Down Discharge

Single Enthalpy Sensor (Outdoor Air Only)

1. Units with economizers already installed: When installing the enthalpy sensor after the economizer has been installed remove the economizer/filter access panel located on the front side of the unit. Remove the mist eliminator and retaining angle from the economizer.




Figure 8.

2. Remove the two screws securing the disk type thermostat to the rear panel.
3. Disconnect the YL/BK and YL wires from the thermostat.
4. Retain the screws for later use and discard the remaining items removed in steps 2 & 3 above.
5. Using the two screws removed in step 2, mount the Enthalpy sensor adjacent to thermostat's previous location, Engagement holes are provided.
6. Replace the mist eliminator.
7. Connect the YL/BK wire to S and the YL wire to + terminal on enthalpy sensor.

Operation

Controller Dial Setting

Control set point scale is located on the Control Module. Control points A, B, C, D are field selectable, and are used for single enthalpy sensing.

The Solid State Enthalpy Sensor is used with a solid state economizer control and damper actuator to proportion an outdoor air damper in a ventilation system.

When using a single enthalpy

control setpoint A, B, C, or D combines temperature and humidity conditions resulting in the control curve shown on the psychrometric chart below.

When the enthalpy of the outdoor air is below (left of) the appropriate curve, the outdoor air damper can proportion open on a call for cooling.

If the outdoor air enthalpy rises above (right of) the control curve, the outdoor air damper will close to minimum position.

For differential enthalpy, you must turn the control set point past D (fully clockwise).

If the outdoor air enthalpy is lower than the return air enthalpy, the outdoor air damper will proportion open on a call for cooling.

If the outdoor air enthalpy is higher than the return air enthalpy, the outdoor air damper will close to minimum position.

If the outdoor air enthalpy and return air enthalpy are equal, the outdoor air damper will proportion open on a call for cooling.




Figure 1.

Troubleshooting

Table 1. Checkout and troubleshooting

Checkout Procedure for Single Sensor	Response
Make sure enthalpy sensor is connected to SO and +. The white resistor must be placed on SR and +.	
Turn enthalpy set point to "A"	LED (light -emitting diode) turns on within a minute.
With power connected, spray a small amount of environmentally safe coolant in upper left vent of sensor to simulate low enthalpy conditions. (See Figure 10)	Terminals 2, 3 closed. Terminals 1, 2 open.
Disconnect power at TR and TR1.	Terminals 2, 3 open. Terminals 1, 2 closed.
Checkout procedure for Differential Enthalpy (Second enthalpy sensor connected to terminals "SR" and "+")	Response
Turn enthalpy set point past "D" (full clockwise).	LED turns off.
With power connected, spray a small amount of refrigerant into upper left vent of sensor connected to SO and + to simulate low outdoor air enthalpy. (See Figure 10).	Terminals 2, 3 closed. Terminals 1, 2 open.
Spray small amount of environmentally safe coolant in upper left vent of return air enthalpy sensor connected to SR and + to simulate low return air enthalpy.	LED turns off. Terminals 2, 3 open. Terminals 1, 2 closed.




Figure 1.

Wiring




Figure 1. Enthalpy sensor wiring when used with BAYECON054, 055 & 73




Figure 2. Economizer with optional differential enthalpy sensors







Figure 3. Economizer with optional outdoor enthalpy sensor

residential applications. For more information, please visit trane.com or americanstandardair.com.
Trane and American Standard have a policy of continuous product and product data improvement and reserve the right to change design and specifications without notice. We are committed to using environmentally conscious print practices.
ACC-SVN85C-EN 22 Nov 2024
Supersedes ACC-SVN85A-EN (July 2024)

Documents / Resources

	<p>TRANE ACC-SVN85C-EN Enthalpy Sensor Control [pdf] Instruction Manual BAYENTH001, BAYECON054, BAYECON055, BAYECON073, BAYECON086A, BAYECON088 A, BAYECON101, BAYECON102, BAYECON105, BAYECON106, ACC-SVN85C-EN Enthalpy S ensor Control, ACC-SVN85C-EN, Enthalpy Sensor Control, Sensor Control, Control</p>
---	---

References

-  [American Standard® | Air Conditioning and Heating | HVAC Systems](#)
-  [Trane Heating & Air Conditioning](#)
- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.