



TST300v3 Precision Temperature Sensor User Manual

[Home](#) » [TST](#) » TST300v3 Precision Temperature Sensor User Manual 

TST300v3 Precision Temperature Sensor User Manual



Contents

- [1 Short description](#)
- [2 Features](#)
- [3 Applications](#)
- [4 Specifications](#)
- [5 Pinout](#)
- [6 Installation](#)
- [7 Installation tips](#)
- [8 Status indicator](#)
- [9 Factory default settings](#)
- [10 Firmware update](#)
- [11 Modbus address table](#)
- [12 Register name](#)
- [13 R/W](#)
- [14 FC](#)
- [15 PDUAddress\(Decimal\)](#)
- [16 Logical Address\(Decimal\)](#)
- [17 Offset \(Decimal\)](#)
- [18 Data size](#)
- [19 Default](#)
- [20 Valid values](#)
- [21 RS-485 address](#)
- [22 Recycling](#)
- [23 Documents / Resources](#)
 - [23.1 References](#)
- [24 Related Posts](#)

Short description

TST300v3/v4 (successors of TST300) is a high accuracy temperature sensor with an RS-485 interface. The device doesn't need external power supply, it is powered through the interface.

The temperature sensor integrates a band-gap temperature sensor element plus signals processing and provides a fully calibrated digital output. The temperature sensors are factorycalibrated. The calibration data is stored in the non-volatile memory. This ensures fully interchangeable of the sensors without any extra efforts.

The sensor is delivered with one-meter standard patch cable with RJ45 connectors. A 19" rack mount kit can be ordered separately.

Features

- RS-485 interface carrying up to 32 nodes
- LED indicator for status of communication
- Changeable bitrate and another communication parameters
- Firmware update via the interface

Applications

- Server room and data centers temperature monitoring and logging
- High precision temperature monitoring and logging for food and drug storages
- Environmental quality monitoring and assessment
- Temperature monitoring in building management systems

Specifications


- Physical characteristics

Dimensions: 85 x 35.1 x 23.5mm

Weight: 40g

- Environmental limits** **Operating temperature range:** -20 to 60°C **Operating relative humidity range:** 10 to 90% (non-condensing) Recommended operating range is 20% to 80% RH (non-condensing) over -10 °C to 60 °C Prolonged operation beyond these ranges may result in a shift of sensor reading, with slow recovery time Long term drift typical: $\pm 0.25\%$ RH/year, $\pm 0.05^\circ\text{C}$ /year Higher drift might occur due to contaminant environments with vaporized solvents, adhesives, packaging materials, etc.
Storage temperature range: -20 to 60°C **Storage relative humidity range:** 10 to 90% (non-condensing) Ingress protection: IP20
- Power requirements** **Operating voltage range** (including -15/+20% according to IEC 62368-1): 4.5 to 26VDC
Current consumption: 7mA@5VDC
- Temperature measurements** **Accuracy (min):** $\pm 0.13^\circ\text{C}$ (in -10 to +60°C range) **Accuracy (max):** $\pm 0.25^\circ\text{C}$ (in -20 to +60°C range) **Resolution:** 0.1°C
- Interface** **Number of bus transceivers:** up to 32 **Response time** $\leq 50\text{ms}$
 - Master response time-out \geq Response time + Answer time The answer time depends on the number of bits and the baud rate
- Warranty** **Warranty period:** 3 years

Pinout

	Pin	Description	UTP wires color
	1	not connected (most right)	Orange/White Tracer
	2	not connected	Orange
	3	not connected	Green/White Tracer
	4	RS485- (B-)	Blue
	5	RS485+ (A+)	Blue/White Tracer
	6	not connected	Green
	7	+VDD	Brown/White Tracer
	8	GND	Brown

Installation

A daisy-chained (linear) topology for multiple sensors should be used. UTP/FTP cables with RJ-45 connectors are used for interconnection. The popular ANSI/TIA/EIA T568B wiring is used. Standard patch LAN cables are recommended.

Attention:

The last sensor in the chain should have a 120 ohm terminator installed on the free RJ-45 socket. The terminator is delivered with the module.



Installation tips

The location and the mounting position of the sensor have a direct effect on the accuracy of the measurement. The tips below will ensure good measuring results:

- Sensor shall be installed about 1.2-1.4 m above the floor;
- To avoid solar radiation, the sensor should not be installed next to windows or directly in the sunlight;
- Sensors shall be installed in a place with sufficient air circulation.
- Sensors shall be wall mounted with vent holes up/down to ensure air circulation.

Status indicator

The status of the device is shown by single LED, located on the front panel:

- If the LED blinks on period of 1 second, sensor works properly;
- If the LED blinks on period of 3 seconds, there isn't communication with the controller;
- If LED doesn't blink, there isn't a power supply.

Factory default settings

Disconnect the sensor from the bus (switch off the power supply).

Press and hold the "config" button. Don't release the button, connecting the sensor to the bus (switch on the power supply).

The "status" LED will be ON for 3 seconds and after this will flash for 7 seconds. After the 10th second the LED will be ON.

Release the button. The sensor will restart with factory default settings.

Firmware update

The firmware of the sensor can be updated with a Teracom controller which supports MODBUS RTU or MBRTU-Update software. For more details ask your dealer.

Modbus address table

Register name	R/ W	FC	PDU address (Decimal)	Logical Address (Decimal)	Offset (Decimal)	Data size	Default	Valid values
---------------	---------	----	-----------------------------	---------------------------------	---------------------	-----------	---------	--------------

RS-485 address	R/ W	03/06	10	40011	40001	16-bit uns. in teger	1	1-247
Baud rate*	R/ W	03/06	11	40012	40001	16-bit uns. in teger	19200	2400, 4800, 9600, 19200, 38400, 57600
Parity, data, stop bits *	R/ W	03/06	12	40013	40001	16-bit uns. in teger	1	1=E81, 2=O81, 3=N81
Data order	R/ W	03/06	13	40014	40001	16-bit uns. in teger	1	1=MSWF (MSW, LSW)2=LSWF (LSW, MSW)
Device code	R	03	14	40015	40001	16-bit uns. in teger		0x00CB
FW version	R	03	15	40016	40001	16-bit uns. in teger		
Vendor URL	R	03	18	40019	40001	64 bytes UTF-8		teracomsystems.com
Float test value (MSWF)	R	03	82	40083	40001	32-bit float		-9.9(0xC11E6666)
Float test value (LSWF)	R	03	84	40085	40001	32-bit float		-9.9(0xC11E6666)
Signed integer test value	R	03	86	40087	40001	16-bit sig. integer		-999(0xFC19)
Signed integer test value(MSWF)	R	03	87	40088	40001	32-bit sig. integer		-99999(0xFFFE7961)
Signed integer test value(LSWF)	R	03	89	40090	40001	32-bit sig. integer		-99999(0xFFFE7961)
Unsigned integer test value	R	03	91	40092	40001	16-bit uns. in teger		999(0x03E7)
Unsigned integer test value(MSWF)	R	03	92	40093	40001	32-bit uns. in teger		99999(0x0001869F)
Unsigned integer test value(LSWF)	R	03	94	40095	40001	32-bit uns. in teger		99999(0x0001869F)
Temperature °C	R	03	100	40101	40001	32-bit float		
Temperature °F	R	03	200	40201	40001	32-bit float		
Temperature multiplier **	R/ W	03/16	2101	42102	40001	32-bit float	1.000	
Temperature offset °C **	R/ W	03/16	2103	42104	40001	32-bit float	0.000	
Temperature offset °F **	R	03	2105	42106	40001	32-bit float	0.000	

The shown logic decimal addresses are calculated with offsets 40001 (holding registers).

MSWF – Most significant word first – (bits 31 ... 16), (bits 15 ... 0); LSWF – Least significant word first – (bits 15 ... 0), (bits 31 ... 16);

PDU address – Actual address bytes used in a Modbus Protocol Data unit When a floating-point value is not available, the returned value is “NaN” (e.g. in case of measurement error).

The settings will take effect after restarting the device by power-off, power-on.

Measured sensor values can be corrected by employing a multiplier and an offset.

The corrections are the results of the following calculations:

Corrected Temperature (°C) = Measured Temperature (°C) × Temperature Multiplier + Temperature Offset (°C)

Using a multiplier and an offset allows precise adjustments to the sensor readings, ensuring accurate temperature values.

It's crucial to emphasize that the multiplier and offset are applicable exclusively in degrees Celsius. After obtaining the corrected temperature in Celsius, it can then be converted to Fahrenheit.

Recycling


Recycle all applicable material.



Do not dispose of with regular household refuse.



Documents / Resources

 The image shows the cover of the user manual for the TST300v3 Precision Temperature Sensor. It features the TeraCom logo at the top, a photograph of the sensor device in the center, and the text 'TST300v3 Precision Temperature Sensor User Manual' and 'www.teracomsystems.com' at the bottom.	<p>TST TST300v3 Precision Temperature Sensor [pdf] User Manual</p> <p>TST300v3, TST300v4, TST300v3 Precision Temperature Sensor, TST300v3, Precision Temperature Sensor, Temperature Sensor, Sensor</p>
--	---

References

- [User Manual](#)

Manuals+, Privacy Policy

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.